



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us


Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Lucas County  
Anchor Pointe Marina F-G Bank  
TNC Water System  
PWS ID #4839112

August 1, 2007

OH4839112 ANCHOR POINTE MARINA F-G BANK 23 08/01/07

Mr. Terry Bourdo  
c/o Anchor Pointe Marina  
Anchor Pointe Marina F-G Bank  
10905 Corduroy Road  
Curtice, Ohio 43412



**Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms**

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

**Monitoring Period:** April - June 2007  
**Required Coliform Sampling:** One sample per quarter  
**Sample Results Submitted:** None

Actions required as a result of the above violation:	
Step 1	<p>Within 30 days issue public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> <li>continuous posting, mail, or other direct delivery; and</li> <li>if necessary, the system must also use any other method reasonably calculated to reach all persons.</li> </ol>
Step 2	<p>Within ten (10) days of completing <b>Step 1</b> above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.</p>

If you have any questions, please contact me at (419) 373-3102.

Sincerely,

Dean A. Twining  
Division of Drinking and Ground Waters

/csi

Enclosures

pc: Toni Buchanan, DDAGW, CO  
Lucas County Health Department  
DDAGW, NWDO File