



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Marion County  
Calvary Bible Baptist Church  
T Non-Community Water System  
PWS ID # OH5137312

December 21, 2007

OH5137312 CALVARY BIBLE BAPTIST CHURCH

22 12/28/07

Pastor Floyd Radebaugh  
Calvary Bible Baptist Church  
1419 Linn-Hipsher Road  
Marion, Ohio 43302



Dear Pastor Radebaugh:

**Subject: Additional Total Coliform Samples Required**

The result of a recent sample submitted for bacteriological analysis is as follows:

Sample Date	Sample Tap Location	Result			Sample/Lab Number
		Total Coliform	Fecal Coliform	E. Coli	
12-17-07	Baptistry	Positive	-	Negative	4693/834

When a bacteriological sample is total coliform positive (unsafe), four repeat samples must be collected. Do not disinfect the well before collecting repeat samples from the following location:

- a. The same sample tap as the total coliform positive (unsafe) sample.
- b. A sample tap within five service connections upstream (before) from the positive (unsafe) tap.
- c. A sample tap within five service connections downstream (after) from the positive (unsafe) tap.
- d. Another sample tap within five service connections upstream or downstream (between b. and c.) from the positive (unsafe) tap.

**NOTE:** If only one sample tap is available, four repeat samples should be collected from that tap at least five (5) minutes apart with the water continuously running OR take the samples at 30-minute intervals.

**IMPORTANT INFORMATION**

- ◆ Collect all four (4) repeat samples on the same day.
- ◆ **Collect the four repeat samples immediately. If we do not receive the results by December 31, 2007, your water system will be placed on a water use advisory.**
- ◆ Identify the exact sample tap on each Sample Submission Report.
- ◆ Mark the Sample Class "**REPEAT SAMPLE**".
- ◆ Record the sample number of the total coliform positive (unsafe) sample on the line after Repeat for Sample # (#4693).

Pastor Floyd Radebaugh  
December 21, 2007  
Page 2

If any of the repeat samples are total coliform positive (unsafe), collect additional sets of four repeat samples until a complete set of four samples is total coliform negative (safe) or until the Maximum Contaminant Level is exceeded.

**Monitor with at least five (5) samples in the next month following any total coliform positive result. Collect at least five (5) samples during the month of January 2008.**

If you have any questions, please contact me at (419) 373-3042.

Sincerely,



Larry Moritz, R.S., M.S.I.H.  
Division of Drinking and Ground Waters

/llr

pc: Marion County Health Department (faxed)  
CDDAGW, NWDO