



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov


Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

OH5142012

ENGLEFIELD OIL COMPANY

6/9/2010

Re: Marion County  
Waldo Duchess Shoppe 235 PWS  
PWS ID#OH5142012  
STU ID#5156237



June 9, 2010

Mr. John S. Gordon, Administrative Contact  
447 James Parkway  
Heath, OH 43056

Dear Mr. Gordon:

The Plant – Distribution Monthly Operation Report (MOR) (EPA Form 5002) for the May 2010 reporting period failed to report daily free and combined chlorine residual at the point of entry to the distribution system and a location representative of the distribution.

OAC 3745-83-01 (G)(1) and (2) requires a transient noncommunity public water system, serving 1,000 or more persons, to monitor for free and combined chlorine residual at least once every day that water is available to the public at each entry point to the distribution system and a representative point in the distribution system. On eleven days, chlorine residuals were not reported.

Failure to take action to address these violations may result in enforcement action being taken.

Questions may be directed to my attention by contacting me at 419-373-3042 or via e-mail to [Larry.Moritz@epa.state.oh.us](mailto:Larry.Moritz@epa.state.oh.us).

Sincerely,

Larry Moritz, R.S, M.S.I.H.  
Division of Drinking and Ground Waters

/lb

pc: Gary Bennett, Operator of Record  
Marion County Health Department

**DDAGW/NWDO**