



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director


Re: Mercer County  
Behms Landing B  
TNC Water System  
PWS ID #5441012

August 1, 2007

General Partner  
Dexter Family LTD  
Behms Landing B.  
5490 Behm Road  
Celina, Ohio 45822

OH5441012 BEHMS LANDING B

23 08/01/07



**Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms**

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

**Monitoring Period:** April - June 2007  
**Required Coliform Sampling:** One sample per quarter  
**Sample Results Submitted:** None

Actions required as a result of the above violation:	
Step 1	Within 30 days issue public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following methods:  1. continuous posting, mail, or other direct delivery; and  2. if necessary, the system must also use any other method reasonably calculated to reach all persons.
Step 2	Within ten (10) days of completing Step 1 above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.

If you have any questions, please contact me at (419) 373-3088.

Sincerely,

John A. (Jack) Schwartz  
Division of Drinking and Ground Waters

JKS/lb

Enclosures

pc: Toni Buchanan, DDAGW, CO  
Mercer County Health Department

~~DDAGW, NWDO File~~