



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korieski, Director

Re: Mercer County  
Doss Landing  
TNC Water System  
PWS ID# OH5437212

December 20, 2007

Mr. Dennis Brown, Owner  
Doss Landing  
8061 State Route 219  
Celina, Ohio 45822

OH5437212 DOSS LANDING

23 12/20/07



Dear Mr. Brown:

**Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms**

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

- Monitoring Period:** November 2007
- Required Coliform Sampling:** Five samples in the month after a coliform-positive
- Sample Results Submitted:** None

Actions required as a result of the above violation:	
Step 1	<p>Within 30 days issue public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> <li>1. continuous posting, mail, or other direct delivery; and</li> <li>2. if necessary, the system must also use any other method reasonably calculated to reach all persons.</li> </ol>
Step 2	<p>Within ten (10) days of completing <b>Step 1</b> above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.</p>

If you have any questions, please contact me at (419) 373-3088.

Sincerely,

*John A. Schwartz / jks*  
John A. (Jack) Schwartz  
Division of Drinking and Ground Waters

JKS/lb

Enclosures

pc: Toni Buchanan, DDAGW, CO  
Mercer County Health Department  
~~DDAGW, NWDO File~~