



State of Ohio Environmental Protection Agency

Northwest

OH5439812 KOZY KAMP GROUND - BATHHOUSE

22 07/02/09

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-84  
www.ep



\* 0 H 5 4 3 9 8 1 2 8 3 9 7 5 0 8 \*

Re: Mercer County  
Kozy Kamp Ground - Bath House Well  
Non-Community, Transient  
PWS ID: OH5439812

July 6, 2009

**NOTICE OF VIOLATION – ACTION REQUIRED**

Mr. Edward A. (Ted) Goodwin  
Kozy Kamp Ground - Bath House Well  
5134 It's It Road  
Celina, Ohio 45822

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During Second Quarter of 2009 (Monthly)**

Kozy Kamp Ground - Bath House Well is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

Sample Date	Sample Tap	Total Coliform	E. coli	Fecal Coliform	Sample Number	Lab Number
06-24-09	#1 well	Positive	Negative	--	62409041	840
06-29-09	#1 well - Lot 4	Positive	Negative	--	62909005	840
06-29-09	#1 well - Lot 155	Positive	Negative	--	62909006	840
06-29-09	#1 well - Lot N151	Positive	Negative	--	62909007	840
06-29-09	#1 well - Lot 112C	Positive	Negative	--	62909008	840

**ACTION REQUIRED:**

- Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
  - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
  - Mail or other direct delivery to each customer;


Mr. Edward A. (Ted) Goodwin  
July 6, 2009  
Page 2

- Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
- Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NWDO. Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). You are required to monitor with five (5) routine samples during July 2009.

If you have any questions, contact this office at 419-373-3088.

Sincerely,



John A. (Jack) Schwartz  
Division of Drinking and Ground Waters

//lr

Enclosures: Tier 2 Public Notification (2)  
Public Notice Instructions and Verification Form

pc: Mercer County Health Department  
Information Management Section, DDAGW, CO  
~~DDAGW - NWDO (w/enclosures)~~