



State of Ohio En

OH5435912

STARLIGHT DRIVE IN THEATER

8/13/2008

Northw

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419)



Re: Mercer County
Starlight Drive In Theater
TNC Public Water System
PWS ID#OH5435912
STU ID#5456451

August 13, 2008

Ms. Joan Myers
515 E. Walnut Street
Coldwater, Ohio 45828-1766

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

This letter is notification that the Starlight Drive In Theater has not complied with requirements issued during this Agency's last survey performed on May 13, 2008, in violation of rule 3745-81-60 of the Ohio Administrative Code. The Starlight Drive In Theater was notified in correspondence dated May 21, 2008, to respond in writing no later than 45 days, with time frames for resolving the following deficiencies:

1. The well cap lacks a screened vent. Replace the well cap with one that securely attaches to the well casing, seals tightly, and incorporates screened vents within its design. (OAC Rule 3745-9-05 P)
2. Add soil around the well casing to a level that directs surface water away. (OAC Rule 3745-9-05 O)
3. Submit specifications of the cartridge filters which precede supply to the ice and pop machines. Specifications shall include: Manufacturer name, Model Number and whether or not the filter conforms to ANSI/NSF Standard 61. (OAC Rule 3745-83-01 D).
4. Maintain an updated Sample Siting Plan for Total Coliform Monitoring by Small Public Water Systems. (OAC Rule 3745-81-21)

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions, please contact me at (419) 373-3042.

Sincerely,

Larry W. Moritz, R.S., M.S.I.H.
Division of Drinking and Ground Waters

/lb

With enclosure

cc: Mercer County Health Dept.
Central Office, DDAGW
~~DDAGW/NWDO~~