



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director


Re: Mercer County
TSC Store 240
TNon-Community Water System
PWS ID #5438412

July 12, 2007

Tractor Supply Company
TSC Store 240
200 Powell Place
Brentwood, Tennessee 37027-7514

OH5438412 TSC STORE 240 PWS

22 07/12/07



Dear Sir or Madam:

**Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria**

Your public water system incurred a **monthly** violation of Rule 3745-81-14 of the Ohio Administrative Code (OAC) in June 2007.

A monthly violation of Rule 3745-81-14 occurs when more than one of your samples within the month were total coliform-positive.


Sample Date	Sample Tap	Total Coliform	Fecal Coliform	<i>E. coli</i>	Sample Number	Lab Cert. Number
06-18-07	Bathroom Faucet	Positive	--	Negative	61807012	840
06-27-07	Bathroom Faucet	Positive	--	Negative	62707013	840

Actions required as a result of the above violation	
Step 1	Within 30 days issue the enclosed public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system: Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.).
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing Step 1 above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in July 2007.

Tractor Supply Company
July 11, 2007
Page 2

If you have any questions, please contact me at (419)373-3088.

Sincerely,



John A. (Jack) Schwartz
Division of Drinking and Ground Waters

Enclosures

pc: Bob Young, Manager
Toni Buchanan, DDAGW, CO
Mercer County Health Department
DDAGW: NWDO File