



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Ottawa County  
Miller's Lime Kiln Dock  
T Non-Community Water System  
PWS ID # 6259512

October 30, 2007

OH6259512

MILLER BOAT LINES

10/30/2007

Mr. Scott Market  
Miller's Lime Kiln Dock  
P.O. Box 248  
Put-In-Bay, Ohio 43456



Dear Mr. Market:


Ohio Administrative Code, Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system.

Review of your monthly reports (EPA 5002) for August and September 2007, indicates that the chlorine residuals were below this level four (4) days during the month of August and seven (7) days during the month of September.

Free and combined residuals are to be conducted at the plant tap and in the distribution system daily.

Please take the necessary steps to correct this deficiency.

Yours truly,

  
Robert A. Plotts  
Division of Drinking and Ground Waters

//lr

Enclosure

pc: Ottawa County Health Department  
Enforcement and Water Quality Section, DDAGW, CO  
DDAGW, NWDO File  
Linda Benham, DDAGW-NWDO