



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Ottawa County  
~~The Skyway~~/South Shore  
TNC Water Systems  
PWS 6237812/6259712

June 30, 2010

OH6237812

SKYWAY RESTAURANT, LLC

6/30/2010

Ms. Susan Thwaite  
The Skyway/South Shore  
P.O. Box 217  
Put-In-Bay, Ohio 43456



Dear Ms. Thwaite:

The April and May 2010, Drinking Water Operation Reports (EPA 5002) have not been received for your public water systems.

Ohio Administrative Code (OAC), Rule 3745-83-01 (I) requires submittal of an operational report no later than the tenth of the month following the month being reported (i.e., May's monthly operational reports should be submitted to the district office no later than June 10<sup>th</sup>).

Continued non-compliance may result in the revocation of operational licenses in addition to other sanctions and penalties.

If you have any questions regarding this letter, please contact me at (419) 373-3007.

Yours truly,

Robert A. Plotts  
Division of Drinking and Ground Waters

//lr

pc: Ottawa County Health Department  
DDAGW, NWDO File

ec: Linda Benham, DDAGW-NWDO

