



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Ottawa County  
J.F. Walleye Micro-Brewery  
TNon-Community Water System  
PWS ID# OH6258712

September 5, 2007

Mr. Chris Zeitler  
J.F. Walleye Micro-Brewery  
7744 Baumhart Road  
Amherst, Ohio 44001

OH6258712 J.F. WALLEYE MICRO-BREWERY

22 09/05/07



Dear Mr. Zeitler:

**Subject: Notice of Violation of Monthly Maximum Contaminant Level  
for Total Coliform Bacteria**

Your public water system incurred a **monthly** violation of Rule 3745-81-14 of the Ohio Administrative Code (OAC) in August 2007.

A monthly violation of Rule 3745-81-14 occurs when more than one of your samples within the month were total coliform-positive.

Sample Date	Sample Tap	Total Coliform	Fecal Coliform	E. coli	Sample Number	Lab Cert. Number
08-21-07	Pressure Tank	Positive	--	Negative	35975	877
08-29-07	Kitchen Deep Sink	Positive	--	Negative	35945	877
08-29-07	Kitchen Restroom	Positive	--	Negative	35942	877
08-29-07	Bar Sink	Positive	--	Negative	35941	877
08-29-07	Men's Restroom	Positive	--	Negative	35946	877

Actions required as a result of the above violation	
Step 1	<p><b>Within 30 days</b> issue the enclosed public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <p>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.).</p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing <b>Step 1</b> above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in September 2007.

Mr. Chris Zeitler  
September 5, 2007  
Page 2

If you have any questions, please contact me at (419) 373-3007.

Sincerely,



Robert A. Plotts  
Division of Drinking and Ground Waters

/csl

Enclosures

pc: Eastwood Environmental, Inc.  
Toni Buchanan, DDAGW, CO  
Ottawa County Health Department  
DDAGW-NWDO File