



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Paulding County  
Transient NC PWS  
5 Span Vacation Land  
PWS ID# OH 6333812  
STU ID# 6362143


October 5, 2011

OH6333812

FB DEVELOPMENT

10/5/2011

Mr. Philip Treglia  
FB Development  
5 Span Vacation Land  
1275 North Cole Street  
Lima, Ohio 45801-3413



Dear Mr. Treglia:

**Subject: Notice of Violation for Failure to Respond to a Significant Deficiency**

This letter is notification that the 5 Span Vacation Land public water system has not complied with requirements issued during this Agency's last survey performed on August 11, 2011, in violation of rule 3745-81-60 of the Ohio Administrative Code. **The PWS was notified in correspondence dated August 19, 2011, to respond in writing no later than 30 days, with time frames for:**

- 1.) OAC Rule 3745-9-05 (P) states "A well shall have a well cap or seal to prevent the entrance of water, dirt, animals, insects, or other foreign matter. The top of the casing at its finished height shall be cut so that the surface will fit flush with the well cap and provide a tight seal. The well cap or seal shall fit securely to the top of the well casing, be secured with screws or other appropriate connections, and vent to the atmosphere...Electrical conduit connections on the well cap or seal shall be threaded and sealed to prevent the entrance of insects and water."

The well does not have the appropriate conduit seal on the cap. Install a cap that includes a conduit connection that meets OAC Rule 3745-9-05 (P).

- 2.) OAC Rule 3745-9-05 (T) states "A vent shall be provided on all well caps and seals...A well vent shall be self-draining, screened with a non-corroding mesh screen of fifteen to thirty mesh, pointed downward at or above the top of the casing or pitless unit. A vent shall terminate not less than twelve inches above ground surface."


Mr. Philip Treglia  
October 5, 2011  
Page 2

The well does not have an appropriate vent on the cap. Install a cap with a vent that meets the specifications identified in OAC 3745-9-05 (T).

**The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.**

If you have any questions regarding this letter, or any other matter involving your water system, contact me at 419-373-3101.

Sincerely,



Chris Riddle  
Environmental Specialist 2  
Division of Drinking and Ground Waters

//lr

pc: Paulding County Health Department  
OEPA Central Office, DDAGW  
<DDAGW;NWDO:File>