




State of Ohio Environmental Protection Agency

Northwes

OH6332112 KINGDOM HALL OF JEHOVA WITNESSES - PA 22 08/12/08

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352
www



NOTICE OF VIOLATION – ACTION REQUIRED

August 12, 2008

RE: Paulding County
Kingdom Hall of Jehovah's Witnesses
Transient Non Community
PWS ID: OH6332112

Kingdom Hall of Jehovah's Witnesses
210 South Main Street
P.O. Box 691
Antwerp, Ohio 45813

Subject: Violation of Total Coliform Maximum Contaminant Level (MCL) During July 2008 (Monthly)

Kingdom Hall of Jehovah's Witnesses is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

Sample Date	Sample Tap	Total Coliform	E. coli	Fecal Coliform	Sample Number	Lab Number
07-28-08	Breakroom Sink	Positive	Negative	--	2241	834
08-06-08	Breakroom Sink	Positive	Negative	--	2388	834
08-06-08	Breakroom Sink	Positive	Negative	--	2387	834
08-06-08	Breakroom Sink	Positive	Negative	--	2386	834
08-06-08	Breakroom Sink	Positive	Negative	--	2385	834

ACTION REQUIRED:

- Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served. The appropriate methods for your system are listed below under the **Transient Non-Community** column.

Community	Transient or Non-Transient Non-Community
<ul style="list-style-type: none"> Mail or other direct delivery to each customer If necessary to reach all persons regularly served, use other notification methods also, such as newspaper publication, public posting or Internet posting 	<ul style="list-style-type: none"> Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas; Mail or other direct delivery to each customer Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper
<p>Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.</p>	

Kingdom Hall of Jehovah's Witnesses
August 12, 2008
Page Two

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - Northwest District Office. Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). You are required to collect five (5) routine samples during the month of August 2008.

If you have any questions, contact this office at 419-373-3007.

Sincerely,



Robert A. Plotts
Division of Drinking and Ground Waters

JKS/cs

Enclosures: Tier 2 Public Notification (2)
Public Notice Instructions and Verification Form

pc: Paulding County Health Department
~~DDAGW - NWDO (w/enclosures)~~
Information Management Section, DDAGW, CO