



State of Ohio Environmental Protection Agency

Northwes OH6944612 AMERICAN LEGION POST 715

22 04/29/08

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352
www



NOTICE OF VIOLATION – ACTION REQUIRED

April 29, 2008

RE: Putnam County
American Legion Post 715
Transient Non-Community Water System
PWS ID: OH6944612

American Legion Post 715
100 Legion Drive
Ft Jennings, OH 45844-0037

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During Second Quarter of 2008 (Monthly)**

American Legion Post 715 is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

Collection Date	Sample Tap	Total Coliform	Results		Sample #	Lab Cert. #
			<i>E. coli</i>	Fecal Coliform		
4-23-08	Kitchen Sink	Positive	Negative	-	95515	877
4-23-08	Women Bath	Positive	Negative	-	91836	877
4-23-08	Bathroom	Positive	Negative	-	91835	877
4-23-08	Left Sink	Positive	Negative	-	91834	877
4-23-08	Left Sink	Positive	Negative	-	78268	877

ACTION REQUIRED:

- Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served. The appropriate methods for your system are listed on Page 2 under the **Transient Non-Community** column.


Community	Transient Non-Community
<ul style="list-style-type: none">• Mail or other direct delivery to each customer• If necessary to reach all persons regularly served, use other notification methods also, such as newspaper publication, public posting or Internet posting	<ul style="list-style-type: none">• Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;• Mail or other direct delivery to each customer• Send to parents or guardians of children at schools or day care facilities• E-mail, newsletters or newspaper
<p><i>Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.</i></p>	

3. Complete the enclosed verification form within 10 days of issuing the Public Notice and mail it to Ohio EPA - Northwest District Office. Include a copy of each notice distributed, published or posted.

4. Monitor with at least five (5) routine samples in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at 419-373-3007.

Sincerely,



Robert A. Plotts
Division of Drinking and Ground Waters

/csf

Enclosures: Tier 2 Drinking Water Notice (2)
Public Notice Instructions and Verification Form

pc: Putnam County Health Department
DDAGW=NWDO!w/Enclosures
IMS, DDAGW, CO – Attn: Toni Buchanan