




Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH6945112 GLANDORF ROD AND GUN CAMPGROUND 22 08/16/11



Re: Putnam County  
Glandorf Rod and Gun Campground  
Non-Community, Transient  
PWS ID: OH6945112

August 18, 2011

**NOTICE OF VIOLATION – ACTION REQUIRED**

Mr. Thomas Hoyt  
Glandorf Rod and Gun Campground  
10471 Township Road I-9  
Ottawa, Ohio 45875-9665

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During August 2011 (Monthly)**

Glandorf Rod and Gun Campground is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**ACTION REQUIRED:**

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
  - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
  - Mail or other direct delivery to each customer;
  - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
  - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
- 3. Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NWDO. Include a copy of each notice distributed, published or posted.

Mr. Thomas Hoyt  
August 18, 2011  
Page 2

4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). You are required to monitor with five (5) routine samples during September 2011.

If you have any questions, contact this office at 419-373-3101.

Sincerely,



Chris Riddle  
Division of Drinking and Ground Waters

/l/r

Enclosures: Tier 2 Public Notification (2)  
Public Notice Instructions and Verification Form

pc: Putnam County Health Department  
Information Management Section, DDAGW, CO  
DDAGW - NWDO (w/enclosures)