



State of Ohio Environmental Protection Agency


Northwest

OH6946012 LOVE-HEITMEYER FUNERAL HOME PWS

25 03/25/09

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8
www.e



NOTICE OF VIOLATION – ACTION REQUIRED

RE: Putnam County
Love-Heitmeyer Funeral Home
Transient Non-Community
PWS ID: OH6946012

March 25, 2009

Love-Heitmeyer Funeral Home
405 East Third Street
Ottawa, Ohio 45875

Subject: Failure to Conduct Required Repeat Total Coliform Monitoring

Love-Heitmeyer Funeral Home is in violation of monitoring requirements for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-21 for March 2009.

Ohio EPA records indicate that a total coliform-positive sample was collected from this water system on 3/4/2009 and the required repeat samples were not collected. To ensure the safety of drinking water provided by your system monitoring with all of the required repeat samples is essential.

IMMEDIATE ACTION REQUIRED:

1. **Consult with Ohio EPA within 24 hours** regarding public notice requirements. If you have not already received direction regarding this violation, contact the Northwest District Office at 419-373-3007.
2. **Issue the enclosed public notice within 24 hours** in accordance with OAC, Rule 3745-81-32 using one or more of the following methods to reach all persons served. The appropriate methods for your system are listed below:

Transient Non-Community

- Hand delivery to persons served by the water system
- Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas
- Send to parents or guardians of children at schools or day care facilities
- Another delivery method approved in writing by the director

Posted notices must remain in place for as long as the violation exists, but in no case for less than seven (7) days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.



Love-Heitmeyer Funeral Home
March 25, 2009
Page 2

NOTE: Issuance of a Public Notice must be repeated every 30 days for as long as the violation exists, unless directed otherwise by the District Office. A verification form and a copy of the public notice, stating the corrective measures completed to date, must be submitted to the Ohio EPA.

3. **Complete the enclosed verification form, within 10 days of issuing the Public Notice** and mail it to Ohio EPA - Northwest District Office. Include a copy of each notice distributed, published or posted.
4. **Collect a set of four (4) repeat samples, until one set is total coliform-negative to discontinue the Water Use Advisory.** Notify the people served by the water system when the water use advisory is discontinued.
5. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). You are required to collect five (5) routine samples during the month of April 2009.

If repeat samples were collected, submit them as soon as possible.

If you have any questions, contact this office at 419-373-3007.

Sincerely,



Robert A. Plotts
Division of Drinking and Ground Waters

/csf

Enclosures: Tier 1 Public Notification (2)
Public Notice Instructions and Verification Form

pc: Putnam County Health Department
•DDAGW – NWDO (w/enclosures)
Information Management Section, DDAGW, CO