




State of Ohio Environmental Protection Agency

OH6946012 LOVE-HEITMEYER FUNERAL HOME PWS

22 03/28/07

Northwest

TELE: (419) 352
www



Re: Putnam County
Love-Heitmeyer Funeral Home
TNon-Community Water System
PWS ID #6946012

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

March 28, 2007

Mr. Jeff Heitmeyer
Love-Heitmeyer Funeral Home
16085 State Route 634
Fort Jennings, Ohio 45844

Dear Mr. Heitmeyer:

**Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria**

Your public water system incurred a **monthly** violation of Rule 3745-81-14 of the Ohio Administrative Code (OAC) in March 2007.

A monthly violation of Rule 3745-81-14 occurs when more than one of your samples within the month were total coliform-positive.

Sample Date	Sample Tap	Total Coliform	Fecal Coliform	<i>E. coli</i>	Sample Number	Lab Cert. Number
03-14-07	Janitorial Sink	Positive	--	Negative	93803	877
03-21-07	Janitorial Sink	Positive	--	Negative	93804	877

Actions required as a result of the above violation	
Step 1	Within 30 days issue the enclosed public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system: Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.).
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing Step 1 above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in April 2007.

Mr. Jeff Heitmeyer
March 28, 2007
Page 2

If you have any questions, please contact me at (419) 373-3007.

Sincerely,



Robert A. Plotts
Division of Drinking and Ground Waters

/csl

Enclosures

pc: Toni Buchanan, DDAGW, CO
Putnam County Health Department
DDAGW-NWDO File