



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH7053612 DOLLAR GENERAL STORE NO 324

22 10/27/10



Re: Richland County
Dollar General Store No 324
Non-Community, Transient
PWS ID: OH7053612

October 27, 2010

NOTICE OF VIOLATION – ACTION REQUIRED

Ms. Jill Elmore
Dollar General Store No 324
100 Mission Ridge
Goodlettsville, Tennessee 37072

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During October 2010 (Monthly)**

Dollar General Store No 324 is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

Sample Date	Sample Tap	Total Coliform	E. coli	Fecal Coliform	Sample Number	Lab Number
10-21-10	None Given	Positive	Negative	--	0000274901	877
10-21-10	None Given	Positive	Negative	--	0000274902	877

ACTION REQUIRED:

- Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Mail or other direct delivery to each customer;

Ms. Jill Elmore
October 27, 2010
Page 2

- Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
- Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

3. Complete the enclosed verification form within 10 days of issuing the Public Notice and mail it to Ohio EPA - NWDO. Include a copy of each notice distributed, published or posted.

4. Monitor with at least five (5) routine samples in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). You are required to monitor with five (5) routine samples during November 2010. You are also required to monitor with two (2) additional routine samples during October 2010.

If you have any questions, contact this office at 419-373-3102.

Sincerely,



Kimberly K. Burnham, R.S.
Division of Drinking and Ground Waters

//lr

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

pc: Richland County Health Department
Information Management Section, DDAGW, CO
DDAGW: - NWDO (w/enclosures) →
McGhee's Technical Water Services, Inc.