



State of Ohio Enviroir OH7240212 DAYS INN

22 09/09/09

Northwes

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-
www.e



Re: Sandusky County
Days Inn
Non-Community, Transient
PWS ID: OH7240212

September 10, 2009

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. George Ruta
Days Inn
2027 Cleveland Road
Sandusky, Ohio 44870

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During September 2009 (Monthly)**

Days Inn is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

Sample Date	Sample Tap	Total Coliform	E. coli	Fecal Coliform	Sample Number	Lab Number
09-03-09	Deep Sink	Positive	Negative	--	190734	877
09-03-09	Deep Sink	Positive	Negative	--	190736	877
09-03-09	Deep Sink	Positive	Negative	--	203011	877

ACTION REQUIRED:

- Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Mail or other direct delivery to each customer;
 - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;



Mr. George Ruta
September 10, 2009
Page 2

- Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NWDO. Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).** You are required to monitor with five (5) routine samples during October 2009.

If you have any questions, contact this office at 419-373-3108.

Sincerely,



JoAnn Sabo
Division of Drinking and Ground Waters

//lr

Enclosures: Tier 2 Public Notification (2)
Public Notice Instructions and Verification Form

pc: Derrick Chennault, Eastwood Environmental (w/enclosures)
Sandusky County Health Department
Information Management Section, DDAGW, CO
DDAGW - NWDO (w/enclosures)

**PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR
NON-COMMUNITY PUBLIC WATER SYSTEMS WITH TIER 2 VIOLATIONS**

The owner or operator of a non-community public water system with a Tier 2 violation or situation shall notify the persons served by the public water system as soon as practical but **no later than 30 days** after the system learns of the violation. Public notice shall be repeated every 3 months as long as the violation or situation persists.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
<p>Use one or more of the following methods to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> Public notice issued by posting in conspicuous locations throughout the distribution system (required to remain posted for as long as the violation exists, but in no case less than 7 days) Public notice issued by mail or other direct delivery to each customer and service connection (where known). 	<p>Describe actual methods used to notify public of the violation:</p> <p>1A. Dates of posting _____</p> <p>1B. Locations of posting _____ _____</p> <p>2. Date of mailing/delivery _____</p>
<p>Schools and Day-Care Facilities must notify parents or guardians of children being served by methods besides posting, such as a newsletter, e-mail notice, or direct mailing</p>	<p>A. Method(s) _____ _____</p> <p>B. Date(s) _____</p>
<p>If the above methods do not reach all persons served, also use any other method reasonably calculated to reach other persons served by the system (e.g. publication in a local newspaper or newsletter, use of e-mail to notify employees or students, or delivery of multiple copies to central locations).</p>	<p>A. Method(s) _____ _____</p> <p>B. Date(s) _____</p>

Complete the enclosed verification form and mail it to Ohio EPA – NWDO. INCLUDE A COPY OF THE PUBLIC NOTICE.

Signature of Responsible Person Date

Printed Name and Title of Responsible Person

Days Inn
OH7240212
Sandusky County
September 2009
Total Coliform Monthly MCL (Vio. Type 22)

<p>For Ohio EPA use only: Date PN received: _____ PN acceptable: _____ PN not acceptable: _____</p>
--