



Northwest I



* 0 H 7 2 5 8 7 1 2 8 3 9 7 2 0 7 *

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-84
www.epi

Re: Sandusky County
F.O.R.M.E.
TNC Water System
PWS ID #7258712

August 1, 2007

Dr. Paul Silcox
F.O.R.M.E.
728 North Stone Street
Fremont, Ohio 43420

Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

- Monitoring Period:** April - June 2007
- Required Coliform Sampling:** One sample per quarter
- Sample Results Submitted:** None

Actions required as a result of the above violation:	
Step 1	<p>Within 30 days issue public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> 1. continuous posting, mail, or other direct delivery; and 2. if necessary, the system must also use any other method reasonably calculated to reach all persons.
Step 2	<p>Within ten (10) days of completing Step 1 above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.</p>

If you have any questions, please contact me at (419) 373-3108.

Sincerely,

JoAnn Sabo
Division of Drinking and Ground Waters

JKS/lb

Enclosures

pc: Toni Buchanan, DDAGW, CO
Sandusky County Health Department

~~DDAGW-NWDO File~~