



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director


Re: Sandusky County
Hidden Hills Golf Club, Inc.
TNon-Community Water System
PWS ID# OH7235112

October 16, 2007

OH7235112 HIDDEN HILLS GOLF CLUB, LLC

22 10/16/07

Mr. Mickey Pierce
Hidden Hills Golf Club, Inc.
4886 County Road 16
Woodville, Ohio 43469



Dear Mr. Pierce:

Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria

Your public water system incurred a monthly violation of Rule 3745-81-14 of the Ohio Administrative Code (OAC) in October 2007.

A monthly violation of Rule 3745-81-14 occurs when more than one of your samples within the month were total coliform-positive.

Table with 7 columns: Sample Date, Sample Tap, Total Coliform, Fecal Coliform, E. coli, Sample Number, Lab Cert. Number. Contains two rows of data for samples taken on 10-09-07.

Table titled 'Actions required as a result of the above violation' with 4 steps detailing regulatory requirements for public notice, investigation, verification, and monitoring.

Mr. Mickey Pierce
October 16, 2007
Page 2

If you have any questions, please contact me at (419) 373-3108.

Sincerely,



JoAnn Sabo
Division of Drinking and Ground Waters

/lr

Enclosures

pc: Toni Buchanan, DDAGW, CO
Sandusky County Health Department
DDAGW-NWDO File