



Northw



\* 0 H 7 2 3 5 1 1 2 8 4 8 9 4 0 7 \*

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419)

Re: Sandusky County  
Hidden Hills Golf Club, Inc.  
TNon-Community Water System  
PWS ID# OH7235112

September 26, 2007.

Mr. Mickey Pierce  
Hidden Hills Golf Club, Inc.  
4886 County Road 16  
Woodville, Ohio 43469

Dear Mr. Pierce:

**Subject: Notice of Violation of Monthly Maximum Contaminant Level  
for Total Coliform Bacteria**

Your public water system incurred a **monthly** violation of Rule 3745-81-14 of the Ohio Administrative Code (OAC) in September 2007.

A monthly violation of Rule 3745-81-14 occurs when more than one of your samples within the month were total coliform-positive.

| Sample Date | Sample Tap         | Total Coliform | Fecal Coliform | <i>E. coli</i> | Sample Number | Lab Cert. Number |
|-------------|--------------------|----------------|----------------|----------------|---------------|------------------|
| 09-10-07    | Pro Shop - Kitchen | Positive       | --             | Negative       | 91107045      | 840              |
| 09-17-07    | Pro Shop - Kitchen | Positive       | --             | Negative       | 91807034      | 840              |
| 09-17-07    | Pro Shop - Kitchen | Positive       | --             | Negative       | 91807035      | 840              |

| Actions required as a result of the above violation |   |
|---|---|
| Step 1  | <b>Within 30 days</b> issue the enclosed public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:<br><br>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.). |
| Step 2  | Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.   |
| Step 3  | Within ten (10) days of completing <b>Step 1</b> above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.  |
| Step 4  | Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in October 2007.   |

Mr. Mickey Pierce  
September 26, 2007  
Page 2

If you have any questions, please contact me at (419) 373-3108.

Sincerely,



JoAnn Sabo  
Division of Drinking and Ground Waters

//lr

Enclosures

pc: Toni Buchanan, DDAGW, CO  
Sandusky County Health Department  
{DDAGW-NWDO File }