



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director


Re: Sandusky County
C M Schermerhorn, MD
TNC Water System
PWS ID# OH7258812

September 18, 2007

Dr. Clara M. Schermerhorn
C.M. Schermerhorn, MD
2539 Hayes Avenue
Fremont, Ohio 43420

OH7258812 C M SCHERMERHORN MD

23 09/18/07



Dear Dr. Schermerhorn:

Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

- Monitoring Period:** August 2007
- Required Coliform Sampling:** Five samples in the month after a coliform-positive
- Sample Results Submitted:** None

Actions required as a result of the above violation:	
Step 1	Within 30 days issue public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following methods: 1. continuous posting, mail, or other direct delivery; and 2. if necessary, the system must also use any other method reasonably calculated to reach all persons.
Step 2	Within ten (10) days of completing Step 1 above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.

If you have any questions, please contact me at (419) 373-3108.

Sincerely,

JoAnn Sabo
Division of Drinking and Ground Waters

JKS/lb
Enclosures

pc: Toni Buchanan, DDAGW, CO
Sandusky County Health Department
~~DDAGW, NWDO File~~