




State of Ohio OH7258812 C M SCHERMERHORN MD

22 08/08/07

North



347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE:

Director
Director

Re: Sandusky County
C M Schermerhorn, MD
TNC Water System
PWS ID #7258812

August 10, 2007

Dr. Clara M. Schermerhorn
C.M. Schermerhorn, MD
2539 Hayes Avenue
Fremont, Ohio 43420

Revised Copy

Dear Dr. Schermerhorn:

Subject: Notice of Violation of Monthly Maximum Contaminant Level for Total Coliform Bacteria

Your public water system incurred a **monthly** violation of Rule 3745-81-14 of the Ohio Administrative Code (OAC) in July 2007.

A monthly violation of Rule 3745-81-14 occurs when more than one of your samples within the month were total coliform-positive.


| Sample Date | Sample Tap | Total Coliform | Fecal Coliform | <i>E. coli</i> | Sample Number | Lab Cert. Number |
|-------------|-------------|----------------|----------------|----------------|---------------|------------------|
| 07-30-07 | Exam Room 1 | Positive | -- | Negative | 73107027 | 840 |
| 07-30-07 | Exam Room 1 | Positive | --- | Negative | 73107028 | 840 |
| 07-30-07 | Exam Room 1 | Positive | -- | Negative | 73107029 | 840 |
| 07-30-07 | Exam Room 1 | Positive | -- | Negative | 73107030 | 840 |
| 07-30-07 | Exam Room1 | Positive | -- | Negative | 73107031 | 840 |

| Actions required as a result of the above violation | |
|---|---|
| Step 1 | Within 30 days issue the enclosed public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system: Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.). |
| Step 2 | Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination. |
| Step 3 | Within ten (10) days of completing Step 1 above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA. |
| Step 4 | Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in August 2007. |

Dr. Clara M. Schermerhorn
August 10, 2007
Page Two

If you have any questions, please contact me at (419) 373-3108.

Sincerely,



JoAnn Sabo
Division of Drinking and Ground Waters

JKS/cs

Enclosures

pc: Toni Buchanan, DDAGW, CO
Sandusky County Health Department
DDAGW-NWDO-File



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Sandusky County
C M Schermerhorn, MD
TNon-Community Water System
PWS ID #7258812

August 8, 2007

Dr. Clara M. Schermerhorn
C.M. Schermerhorn, MD
2539 Hayes Avenue
Fremont, Ohio 43420

Dear Dr. Schermerhorn:

**Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria**

Your public water system incurred a **monthly** violation of Rule 3745-81-14 of the Ohio Administrative Code (OAC) in July 2007.

A monthly violation of Rule 3745-81-14 occurs when more than one of your samples within the month were total coliform-positive.

| Sample Date | Sample Tap | Total Coliform | Fecal Coliform | E. coli | Sample Number | Lab Cert. Number |
|-------------|-------------|----------------|----------------|----------|---------------|------------------|
| 07-30-07 | Exam Room 1 | Positive | -- | Negative | 73107027 | 840 |
| 07-30-07 | Exam Room 1 | Positive | -- | Negative | 73107028 | 840 |
| 07-30-07 | Exam Room 1 | Positive | -- | Negative | 73107029 | 840 |
| 07-30-07 | Exam Room 1 | Positive | -- | Negative | 73107030 | 840 |
| 07-30-07 | Exam Room 1 | Positive | -- | Negative | 73107031 | 840 |

| Actions required as a result of the above violation | |
|---|---|
| Step 1 | Within 30 days issue the enclosed public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system: Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.). |
| Step 2 | Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination. |
| Step 3 | Within ten (10) days of completing Step 1 above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA. |
| Step 4 | Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform |

Dr. Clara M. Schermerhorn
August 8, 2007
Page 2

If you have any questions, please contact me at (419) 373-3108.

Sincerely,



JoAnn Sabo
Division of Drinking and Ground Waters

/llr

Enclosures

pc: Toni Buchanan, DDAGW, CO
Sandusky County Health Department
(DDAGW-NWDO File . . . ;