



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Sandusky County
C. M. Schermerhorn, M.D.
T Non-Community Water System
PWS ID # 7258812

OH7258812 C M SCHERMERHORN MD

22 06/04/07

June 4, 2007

C M Schermerhorn, MD
2539 Hayes Ave
Fremont, OH 43420



Subject: Notice of Violation of Monthly Maximum Contaminant Level for Total Coliform Bacteria

Your public water system incurred a **monthly** violation of Ohio Administrative Code (OAC), Rule 3745-81-14 in May, 2007 due to the following results:

Sample Date	Sample Tap	Total Coliform	E. Coli	Fecal Coliform	Sample Number	Lab Cert Number
5-14-07	Room 1	Positive	Negative	-	51507024	840
5-22-07	Exam Rm 1	Positive	Negative	-	52307028	840
5-22-07	Exam Rm 1	Positive	Negative	-	52307027	840
5-22-07	Exam Rm 1	Positive	Negative	-	52307026	840
5-22-07	Exam Rm 1	Positive	Negative	-	52307025	840
5-22-07	Exam Rm 1	Positive	Negative	-	52307024	840

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	Within 30 days issue the attached public notice of the violation in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served by the public water system: Posting in conspicuous locations (restrooms, drinking fountains, vending areas, bulletin boards, etc.).
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within 10 days of completing Step 1, fill out the attached verification form and send it along with a copy of the public notification issued to the Ohio EPA, Northwest District Office.
Step 4	You are required to monitor with at least five (5) samples in the next month following any total coliform-positive result. You must take at least five (5) total coliform samples in June, 2007.

C.M. Schermerhorn
June 4, 2007
Page Two

If you have any questions, please contact me at (419) 373-3108.

Sincerely,



JoAnn Sabo
Division of Drinking and Ground Waters

JW/lb

Enclosures

pc: Toni Buchanan, DDAGW, CO
Sandusky County Health Department
~~DDAGW=NWBG-File~~