



State of Ohio Environmental Protection Agency

Northwest District Office


Could not locate file copy -> this replaces the file copy

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director
22 10/31/08

OH7432212 CLINTON LAKE CAMPING 1 PWS



NOTICE OF VIOLATION - ACTION REQUIRED

October 31, 2008

RE: Seneca County
Clinton Lake Camping 1
Transient Non Community
PWS ID: OH7432212

Clinton Lake Camping
4990 E Twp Rd 122
Republic, Ohio 44867

Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During October 2008 (Monthly)

Clinton Lake Camping 1 is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

Sample Date	Sample Tap	Total Coliform	E. coli	Fecal Coliform	Sample Number	Lab Number
10-06-08	Lot 56	Positive	Negative	--	3148	834
10-28-08	Lot 62	Positive	Negative	--	3466	834

ACTION REQUIRED:

- Investigate and eliminate the cause of bacterial contamination. Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- Notify the people served by this water system. Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served. The appropriate methods for your system are listed below under the **Transient Non-Community** column.

Community	Transient or Non-Transient Non-Community
<ul style="list-style-type: none"> Mail or other direct delivery to each customer If necessary to reach all persons regularly served, use other notification methods also, such as newspaper publication, public posting or Internet posting 	<ul style="list-style-type: none"> Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas; Mail or other direct delivery to each customer Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper
<p>Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.</p>	

Clinton Lake Camping
October 31, 2008
Page Two

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - Northwest District Office. Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). You are required to monitor with five (5) routine samples before opening for the 2009 season.

If you have any questions, contact this office at 419-373-3007.

Sincerely,

Robert A. Plotts
Division of Drinking and Ground Waters

JKS/lb

Enclosures: Tier 2 Public Notification (2)
Public Notice Instructions and Verification Form

pc: Seneca County Health Department
(DDAGW - NWDO (w/enclosures))
Information Management Section, DDAGW, CO