



State of Ohio Env OH7435712 JOLLYS DRIVE IN PWS

23 08/01/07

Northwe

TELE: (419) 5  
w



347 North Dunbridge Road  
Bowling Green, OH 43402-9398

Re: Seneca County  
Jolly's Drive-In  
TNC Water System  
PWS ID #7435712

August 1, 2007

Mr. Tom Hoyda, Owner  
Jolly's Drive-In  
2255 East Township Road 122  
Tiffin, Ohio 44883

**Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms**

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

**Monitoring Period:** April - June 2007  
**Required Coliform Sampling:** One sample per quarter  
**Sample Results Submitted:** None

Actions required as a result of the above violation:	
Step 1	<p>Within 30 days issue public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> <li>1. continuous posting, mail, or other direct delivery; and</li> <li>2. if necessary, the system must also use any other method reasonably calculated to reach all persons.</li> </ol>
Step 2	<p>Within ten (10) days of completing <b>Step 1</b> above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.</p>

If you have any questions, please contact me at (419) 373-3007.

Sincerely,

Robert A. Plotts  
Division of Drinking and Ground Waters

JKS/lb

Enclosures

pc: Toni Buchanan, DDAGW, CO  
Seneca County Health Department  
DDAGW\NWDO\File