



State of Ohio Environmental Protection Agency

North

OH7430012 LEAFY OAKS CAMPGROUND INC.

22 06/23/10

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (4



* 0 H 7 4 3 0 0 1 2 7 3 7 6 4 1 0 *

error
error
ector

NOTICE OF VIOLATION – ACTION REQUIRED

June 23, 2010

RE: Seneca County
Leafy Oaks Campground, Inc.
Non-Community, Transient
PWS ID: OH7430012

Ms. E Joan Faneuff
Leafy Oaks Campground, Inc.
6955 State Route 101 North
Clyde, Ohio 43410

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During Second Quarter of 2010 (Monthly)**

Leafy Oaks Campground, Inc. is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

Sample Date	Sample Tap	Total Coliform	E. coli	Fecal Coliform	Sample Number	Lab Number
06-11-10	Space 333	Positive	Negative	--	225823	877
06-17-10	Well Tap	Positive	Negative	--	225867	877
06-17-10	Well Tap	Positive	Negative	--	225868	877

ACTION REQUIRED:

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Mail or other direct delivery to each customer;
 - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;




Ms. Joan Faneuff
June 23, 2010
Page Two

- Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NWDO. Include a copy of each notice distributed, published or posted.
 4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). You are required to monitor with five (5) routine samples during July 2010.

If you have any questions, contact this office at 419-373-3007.

Sincerely,



Robert A. Plotts
Division of Drinking and Ground Waters

/lb

Enclosures: Tier 2 Public Notification (2)
Public Notice Instructions and Verification Form

pc: Seneca County Health Department
Information Management Section, DDAGW, CO
~~DDAGW@NWDO~~ (w/enclosures)