



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 19, 2007

Re: Van Wert County  
ODOT - Rest Area 1-28  
TNC Water System  
PWS ID# OH8136712

Mr. Tim Burkepile  
District Deputy Director  
Ohio Department of Transportation  
District One Headquarters  
1885 North Mccullough Street  
Lima, Ohio 45801

OH8136712 ODOT REST AREA 1-28 WB



24 10/19/07

Dear Mr. Burkepile:

**Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms**

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

- Monitoring Period:** September 2007
- Required Coliform Sampling:** Five samples in the month after a coliform-positive
- Sample Results Submitted:** One sample on September 12, One sample on September 19 and Two samples on September 26, 2007

Actions required as a result of the above violation:	
Step 1	Within 30 days issue public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following methods:  1. continuous posting, mail, or other direct delivery, and  2. if necessary, the system must also use any other method reasonably calculated to reach all persons.
Step 2	Within ten (10) days of completing Step 1 above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.

If you have any questions, please contact me at (419) 373-3007.

Sincerely,

Robert A. Plotts  
Division of Drinking and Ground Waters  
/csl

Enclosures

pc: Anthony D. Lotz, Facilities Manager  
Tom Horn, Industrial Fluid Management  
Toni Buchanan, DDAGW, CO  
Van Wert County Health Department  
(DDAGW, NWDO File)