



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director


Re: Van Wert County
ODOT Rest Area 1-28
TNon-Community Water System
PWS ID #8136712

August 8, 2007

Mr. Tim Burkepile, District Deputy Director
Ohio Department of Transportation
District One Headquarters
1885 North McCullough Street
Lima, Ohio 45801

OH8136712 ODOT REST AREA 1-28 WB

22 08/08/07



Dear Mr. Burkepile:

**Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria**

Your public water system incurred a **monthly** violation of Rule 3745-81-14 of the Ohio Administrative Code (OAC) in August 2007.

A monthly violation of Rule 3745-81-14 occurs when more than one of your samples within the month were total coliform-positive.


Sample Date	Sample Tap	Total Coliform	Fecal Coliform	E. coli	Sample Number	Lab Cert. Number
08-01-07	Mop Sink #1	Positive	--	Negative	12233	833
08-01-07	Mop Sink #2	Positive	--	Negative	12232	833

Actions required as a result of the above violation	
Step 1	Within 30 days issue the enclosed public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system: Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.).
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing Step 1 above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in September 2007. You also need to collect three (3) more samples in August 2007.

Mr. Tim Burkepile, District Director
August 8, 2007
Page 2

If you have any questions, please contact me at (419) 373-3007.

Sincerely,



Robert A. Plotts
Division of Drinking and Ground Waters

/lr

Enclosures

pc: Anthony D. Lotz, Facilities Manager
Tom Horn, Operator of Record
Toni Buchanan, DDAGW, CO
Van Wert County Health Department
(DDAGW-NWDO File)