



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Van Wert County
Rambler's Roost
TNon-Community Water System
PWS ID# OH8131212

September 28, 2007

Ms. Penny Burnett
Rambler's Roost
18191-A Lincoln Highway
Middle Point, Ohio 45863

OH8131212 RAMBLERS ROOST



22 09/28/07

Dear Ms. Burnett:

**Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria**

Your public water system incurred a **monthly** violation of Rule 3745-81-14 of the Ohio Administrative Code (OAC) in September 2007.

A monthly violation of Rule 3745-81-14 occurs when more than one of your samples within the month were total coliform-positive.

Sample Date	Sample Tap	Total Coliform	Fecal Coliform	E. coli	Sample Number	Lab Cert. Number
09-11-07	Island Spigot	Positive	--	Negative	12484	833
09-11-07	Island Spigot	Positive	--	Negative	12485	833

Actions required as a result of the above violation	
Step 1	Within 30 days issue the enclosed public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system: Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.).
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing Step 1 above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in October 2007.

If you have any questions, please contact me at (419) 373-3007.

Ms. Penny Burnett
September 28, 2007
Page 2

If you have any questions, please contact me at (419) 373-3007.

Sincerely,



Robert A. Plotts
Division of Drinking and Ground Waters

/lr

Enclosures

pc: Toni Buchanan, DDAGW, CO
Van Wert County Health Department
C:DDAGW-NWDO File]