



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Wood County
Sunoco 7613
TNC Water System
PWS ID# OH8750412

January 17, 2008

Ms. Anna Morley
Sunoco, Incorporated
Sunoco Store #7613
Ten Penn Center - 20th Floor
1801 Market Street
Philadelphia, Pennsylvania 19103-1699

OH8750412 SUNOCO FOOD MART 10 - HOP IN

23 01/17/08



Dear Ms. Morley:

Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

- Monitoring Period:** December 2007
- Required Coliform Sampling:** Five samples in the month after a coliform-positive
- Sample Results Submitted:** Four samples collected on December 14, 2007

Actions required as a result of the above violation	
Step 1	Within 30 days issue public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following methods: 1. continuous posting, mail, or other direct delivery; and 2. if necessary, the system must also use any other method reasonably calculated to reach all persons.
Step 2	Within ten (10) days of completing Step 1 above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.

If you have any questions, please contact me at (419) 373-3007.

Sincerely,

Robert A. Plotts
Division of Drinking and Ground Waters
/csi

Enclosures
pc: Manager (w/enclosure)
Charles S. Klaus, Project Manager (w/enclosure)
Toni Buchanan, DDAGW, CO
Wood County Health Department
(DDAGW, NWDO File)