



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Wood County  
Sunoco Store #7613  
T Non-Community Water System  
PWS ID # OH8750412

November 21, 2007

Ms. Anna Morley  
Sunoco, Inc  
Ten Penn Center - 20th Floor  
1801 Market St  
Philadelphia, Pennsylvania 19103-1699

OH8750412 SUNOCO FOOD MART 10 - HOP IN 22 11/21/07



**Subject: Notice of Violation -  
Monthly Maximum Contaminant Level for Total Coliform Bacteria**

Sunoco Store #7613 public water system incurred a **monthly** violation of Ohio Administrative Code (OAC), Rule 3745-81-14 in November, 2007 due to the following results:

Sample Date	Sample Tap	Total Coliform	E. Coli	Fecal Coliform	Sample Number	Lab Cert Number
11-16-07	3 Basin Sink	Positive	Negative	-	36050	877
11-16-07	3 Basin Sink	Positive	Negative	-	36051	877
11-16-07	3 Basin Sink	Positive	Negative	-	36052	877


A monthly violation of OAC, Rule 3745-81-14 occurs when more than one sample within the month is total coliform-positive.

Actions required as a result of the above violation	
Step 1	<b>Within 30 days</b> issue the attached public notice of the violation in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served by the public water system:  Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.).
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within <b>10 days</b> of completing Step 1, fill out the attached verification form and send it along with a copy of the public notification issued to the Ohio EPA, Northwest District Office.
Step 4	You are required to monitor with at least five (5) samples in the next month following any total coliform-positive result. Five (5) total coliform samples are required during December, 2007.

Ms. Anna Morley  
November 21, 2007  
Page 2

If you have any questions, please contact me at (419) 373-3007.

Sincerely,



Robert A. Plotts  
Division of Drinking and Ground Waters

JW/lir

Enclosures

pc: Manager  
Charles S. Klaus, PG  
Toni Buchanan, DDAGW, CO  
Wood County Health Department  
DDAGW-NWDO