



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Wood County  
Sunoco #7613  
TNon-Community Water System  
PWS ID# OH8750412

August 29, 2007

Ms. Anna Morley  
Sunoco, Inc. - Sunoco Store #7613  
Ten Penn Center - 20<sup>th</sup> Floor  
1801 Market Street  
Philadelphia, Pennsylvania 19103-1699

OH8750412 SUNOCO FOOD MART 10 - HOP IN

22 08/29/07



Dear Ms. Morley:

**Subject: Notice of Violation of Monthly Maximum Contaminant Level for Total Coliform Bacteria**

Your public water system incurred a **monthly violation** of Rule 3745-81-14 of the Ohio Administrative Code (OAC) in August 2007.

A monthly violation of Rule 3745-81-14 occurs when more than one of your samples within the month were total coliform-positive.

Sample Date	Sample Tap	Total Coliform	Fecal Coliform	<i>E. coli</i>	Sample Number	Lab Cert. Number
08-23-07	Three Basin Sink	Positive	--	Negative	27576	877
08-23-07	Women's Restroom	Positive	--	Negative	27577	877

Actions required as a result of the above violation	
Step 1	<p><b>Within 30 days</b> issue the enclosed public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <p>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.).</p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing <b>Step 1</b> above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in September 2007.

Ms. Anna Morley  
August 29, 2007  
Page Two

If you have any questions, please contact me at (419)373-3007.

Sincerely,



Robert A. Plotts  
Division of Drinking and Ground Waters

JKS/cs

Enclosures

pc: Manager  
Toni Buchanan, DDAGW, CO  
Wood County Health Department  
~~DDAGW:NWDO:File~~  
Charles S. Klaus, P.G.; Project Manager