



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director


Re: Huron County
Wiers Farm AMLC 4B-Bldg 3&4
TNC Water System
PWS ID# OH3946512

September 18, 2007

Mr. David Wiers
Wiers Farm AMLC #4B - Bldg 3&4
4465 State Route 103 South
P.O. Box 385
Willard, Ohio 44890

OH3946512 WIERS FARM AMLC 3/4B

24 09/18/07



Dear Mr. Wiers:

Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms


Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

- Monitoring Period:** August 2007
- Required Coliform Sampling:** Five samples in the month after a coliform-positive
- Sample Results Submitted:** Four samples collected on August 6, 2007

Actions required as a result of the above violation:	
Step 1	<p>Within 30 days issue public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> 1. continuous posting, mail, or other direct delivery; and 2. if necessary, the system must also use any other method reasonably calculated to reach all persons.
Step 2	<p>Within ten (10) days of completing Step 1 above, fill out the enclosed verification form and send it and a copy of the public notification issued to the Northwest District Office of Ohio EPA.</p>

If you have any questions, please contact me at (419) 373-3102.

Sincerely,


 Dean A. Twining
 Division of Drinking and Ground Waters
 JKS/lb
 Enclosures

pc: Toni Buchanan, DDAGW, CO
 Scott Golden, ODH, CO
 Huron County Health Department
 DDAGW-NWDO File