



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korteski, Director

OH7249812

HETRICK AMLC

12/14/2010



Re: Sandusky County  
Hetrick AMLC  
TNC Water System  
PWS ID# OH7249812  
STU ID# 7257998

December 14, 2010

Certified Mail 7009 1680 0002 4297 3619

Mr. Jerry Hetrick  
Hetrick AMLC  
3394 County Road 106  
Lindsey, Ohio 43442

Dear Mr. Hetrick:

**Subject: Notice of Violation for Failure to Respond to a Significant Deficiency**

This letter is notification that the Hetrick AMLC has not complied with requirements issued during this Agency's last survey performed on September 23, 2010, in violation of rule 3745-81-60 of the Ohio Administrative Code (OAC). The AMLC was notified in correspondence dated October 21, 2010, to respond in writing no later than 45 days, with time frames for:

1. A Siting Plan for Total Coliform monitoring was not on file. Prepare a Total Coliform Sample Siting Plan for Total Coliform as required by OAC Rule 3745-81-21. A plan was started with Mr. Hurst during the survey. This plan should be completed, updated as necessary, and remain on file. No response or further action is required for this item.
2. OAC Rule 3745-9-04(A)(6) states, "Potential sources of contamination shall not be constructed or placed within the sanitary isolation radius of a public water system well." The roadway and an agricultural field are within the isolation radius. Attention should be paid to potential sources of contamination from the roadway and agricultural operation in case of a spill, chemical application, or accident. No response is required for this item.
3. OAC Rule 3745-9-05(P) states "A well shall have a well cap or seal to prevent the entrance of water, dirt, animals, insects, or other foreign matter. The top of the casing at its finished height shall be cut so that the surface will fit flush with the well cap and provide a tight seal. The well cap or seal shall fit securely to the top of the well casing, be secured with screws or other appropriate connections, and vent to the atmosphere ... Electrical conduit connections on the well cap or seal shall be threaded and sealed to prevent the entrance of insects and water." The well does not have the appropriate conduit seal on the cap. Install a cap on that includes a conduit connection that meets OAC Rule 3745-9-05 (P).

Mr. Jerry Hetrick  
December 14, 2010  
Page Two

4. OAC Rule 3745-9-05(T) states "A vent shall be provided on all well caps and seals ... A well vent shall be self-draining, screened with a non-corroding mesh screen of fifteen to thirty mesh, pointed downward at or above the top of the casing or pitless unit. A vent shall terminate not less than twelve inches above ground surface." The well does not have an appropriate vent on the cap. Install a cap with a vent that meets the specifications identified in OAC 3745-9-05(T).
5. OAC Rule 3745-95-04(A) states "An approved backflow prevention device shall be installed on each service line to a consumer's water system serving premises, where in the judgment of the supplier of water or the director, a pollutional, system, health or severe health hazard to the public water system exists." Ensure that an approved backflow prevention device is installed on each service line where a pollutional, system, health or severe health hazard to the public water system exists. Such a device should be installed on the external hose bibb or a new bibb should be installed with an integrated vacuum breaker.
6. OAC Rule 3745-81-21(A)(2) states "A non-community water system using only ground water or purchased water and serving not more than one thousand persons shall monitor with at least one sample each calendar quarter that the non-community water system provides water to the public." If the camp remained in operation after September 30, 2010, a quarterly total coliform sample is required for the fourth quarter.
7. OAC Rule 3745-81-21(C) states "Failure to comply with a coliform monitoring requirement ... is a monitoring violation. A public water system which has failed to comply with a coliform monitoring requirement ... shall ... notify the public ..." Public notice has not been provided for three past violations. Two copies of each and verification forms have been included with this package. Complete the notice forms and verification forms. Post one copy of each notice and return the verification forms and a copy of each notice to my attention.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions regarding this letter, or any other matter involving your water system, contact me at 419-373-3101.

Sincerely,



Chris Riddle  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/cs  
pc:

Don Hurst  
Gene Phillips, Ohio Department of Health  
Central Office, DDAGW  
DDAGW-NWDO.File

SENDER: COMPLETE THIS SECTION	COMPLETE THIS SECTION ON DELIVERY
<ul style="list-style-type: none"> <li>Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.</li> <li>Print your name and address on the reverse so that we can return the card to you.</li> <li>Attach this card to the back of the mailpiece, or on the front if space permits.</li> </ul>	A. Signature <input checked="" type="checkbox"/> <i>Jerry Hetrick</i> <input type="checkbox"/> Agent <input checked="" type="checkbox"/> Addressee
1. Article Addressed to: <i>Mr. Jerry Hetrick            Hetrick AM&amp;C            3394 Co. Rd. 106            Lindsay, Ohio            43442</i>	B. Received by (Printed Name) <i>JERRY HETRICK</i> C. Date of Delivery <i>12-15-10</i>
	D. Is delivery/address different from item 1? <input type="checkbox"/> Yes If YES, enter delivery address below: <input checked="" type="checkbox"/> No
	3. Service Type <input checked="" type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.
	4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes
2. <u>7</u>	

PS Form 3800, February 2007

5-02-M-1540

U.S. Postal Service™ <b>CERTIFIED MAIL™ RECEIPT</b> (Domestic Mail Only; No Insurance Coverage Provided)	
For delivery information visit our website at <a href="http://www.usps.com">www.usps.com</a>	
<b>OFFICIAL USE</b>	
Postage \$ <i>44</i>	<b>Ohio EPA</b>
Certified Fee	Postmark Here
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees \$ <i>5.54</i>	
Sent To <i>Hetrick AM&amp;C</i>	
Street, Apt. No.; or PO Box No. <i>3394 Co. Rd. 106</i>	
City, State, ZIP+4 <i>Lindsay, Ohio 43442</i>	
PS Form 3800, August 2006	See Reverse for Instructions

7009 1680 0002 4297 3619