




Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH8639612

STUCKEY AMLC

1/11/2011



Re: Williams County  
TNC Water System  
Stuckey AMLC  
PWS ID # OH 8639612

January 11, 2011

CERTIFIED MAIL

Mr. Douglas Stuckey  
4378 County Road 25  
Archbold, Ohio 42502

Dear Mr. Stuckey

**Subject: Notice of Violation for Failure to Respond to a Significant Deficiency**

This letter is notification that the Stuckey AMLC has not complied with requirements issued during this Agency's last survey performed on August 18, 2010, in violation of rule 3745-81-60 of the Ohio Administrative Code. The AMLC was notified in correspondence dated September 22, 2010, and again notified on November 22, 2010, to respond in writing with time frames for:

1. Install a screen on the pipe for the well overflow system to prevent contaminants from entering the well.
2. The electrical conduit connection on the well cap is not sealed. Electrical conduit connections on the well cap must be threaded and sealed to prevent the entrance of insects and water. [OAC Rule 3745-9-05(P)]
3. A vent shall be provided on all well caps and seals. The well does not have an appropriate vent on the cap. Install a vent on the well cap that is self-draining, screened with a non-corroding mesh screen of fifteen to thirty mesh, and pointed downward at or above the top of the casing or pitless unit. The vent should terminate not less than twelve inches above ground surface. [OAC 3745-9-05 (T)]
4. Re-grade the soil around the well. The finished grade must be sloped for surface water to runoff away from the well. [OAC Rule 3745-9-05 (O)]
5. Public water systems shall collect total coliform routine samples at sites which are representative of water throughout the distribution system according to a written sample siting plan.

Northwest District Office  
347 North Dunbridge Road  
Bowling Green, OH 43402-9398

419 | 352 8461  
419 | 352 8468 (fax)  
www.epa.ohio.gov

Mr. Douglas Stuckey  
January 11, 2011  
Page 2


A written total coliform sample siting plan was not available, but was prepared during the survey. No further action is required; however, the plan should be maintained and updated as required. [OAC Rule 3745-81-21(A)]

6. A non-community water system using only ground water and serving not more than one thousand persons shall monitor with at least one sample *each quarter that the non-community water system provides water to the public*. Monitor with at least one routine total coliform sample from the distribution system quarterly during the operating season. In order to remain in compliance, you must continue to monitor in accordance with your schedule. [OAC Rule 3745-81-21(A)(2)(a)]
7. Antifreeze may not be run through the plumbing when the system is shut down. All chemicals, substances or materials brought in contact with water must conform to "American National Standards Institute/National Sanitation Foundation" ANSI/NSF standard 60 Drinking Water Treatment Chemicals – Health Effects (2005 and previous), or standard 61 Drinking Water System Components – Health Effects (2005 and previous). [OAC Rule 3745-83-01(D)]

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions, please contact me at (419) 373-3107.

Sincerely,



Elizabeth Ames  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/lr

pc: Gene Phillips, Ohio Department of Health  
Central Office, DDAGW  
~~DDAGW, NWDO~~  
Certified Receipt Number 7009 1410 0001 1839 9911

ec: Linda Benham, DDAGW, NWDO

7009 1410 0001 1839 9901

U.S. Postal Service™  
**CERTIFIED MAIL™ RECEIPT**  
(Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at [www.usps.com](http://www.usps.com)

**OFFICIAL USE**

|   |        |   |
|---|--------|---|
| Postage   | \$ 44  | Ohio EPA  |
| Certified Fee                                     | 280    |   |
| Return Receipt Fee<br>(Endorsement Required)      |        |   |
| Restricted Delivery Fee<br>(Endorsement Required) |        |   |
| Total Postage & Fees                              | \$ 324 | Postmark Here<br>JAN 11 2011<br>GREEN, OHIO 43402<br>USPS |

Sent To  
Mr. Douglas  
Street, Apt. No. or PO Box No. 4378 Co. Rd. 85  
City, State, ZIP+4  
ANCHARD OH 42502