



**Environmental  
Protection Agency**

John Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott J. Hardy, **Director**



**NOTICE OF VIOLATION – ACTION REQUIRED**

September 26, 2012

Christopher Cook  
P.O. Box 362  
Gratiot, OH 43740

**Licking County  
East End Water Co  
COMMUNITY PWS  
PWS ID: OH4566112**

This letter is notification that East End Water Co. in violation of the Ohio Administrative Code (OAC) 3745-83-01(G) (1) for August 2012, as the public water system failed to monitor for free or combined chlorine at least once every day that water is available to the public at each entry point to the distribution system and a representative point or points in the distribution system. There were no samples taken at the entry point during the month.

This violation does not require public notification. However, please review your operations to determine the reason for the missing analyses and advise this office as to what corrections will be made.

If you have any questions, please contact me directly at (614) 728-3863.

Respectfully,

Katie A. Anderson, E.I.  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office  
ec: CDO DDAGW AA (State Violation)

KA/ct 4566112(MI)AUG2012