



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 23, 2009

RE: OHIO DEPT. OF NATURAL RESOURCES
PYMATUNING WWTP
PERMIT NO. 3PP00013
ASHTABULA COUNTY
WILLIAMSFIELD TOWNSHIP

CERTIFIED MAIL

Mr. Phil Vichosky, Park Manager
P.O. Box 1000
Andover, Ohio 44003

Dear Mr. Vichosky:

On September 24, 2009, an inspection of the above referenced facility's wastewater treatment system was conducted. The facility was represented by Al Shiner, Wastewater Treatment Plant Operator. The purpose of the inspection was to evaluate the operation and maintenance of the treatment systems along with the facility's compliance status with respect to the terms and conditions of the above referenced National Pollutant Discharge Elimination System (NPDES) permit.

During the inspection, the following items were noted/discussed:

**Campground Area WWTP
(Station 001)**

1. The muffin monster was broken. The motor needs replaced. Currently a manual bar screen is being used.
2. The blowers were running and the plant was receiving good aeration.
3. The contents of the aeration tank were medium brown in color and no foam was present.
4. The skimmer return line was functioning properly and returning clear water.
5. The sludge return line was functioning; however, the return was very light brown. Mr. Shiner indicated sludge was wasted the day before.
6. The weirs and the sidewalls in the settling tank were free of scum build-up.
7. One side of the plant is going to be taken down for the winter months. Maintenance is going to be performed and then potable water is going to be added back in.
8. The south wall of the west sand filter bed and the center south wall both leak. These need to be repaired immediately.
9. Minimal vegetation was present in 2 of 6 of the surface sand filter beds. These beds should be maintained free of all vegetation.
10. Filter media had recently been installed in 4 of 6 beds.
11. The effluent was clear.

12. Three large, three medium and two small lift stations are connected to the wastewater treatment plant.
13. Both Sigma automatic samplers need repaired.
14. Currently, the flow proportioned chlorine feed is hooked up but is not being operated off the automatic system. This needs to be corrected immediately.
15. The caustic soda feed is also not being operated off the automatic system. This also needs to be corrected. Currently, pH is being adjusted based on the raw flow rate.

**Beach/Marina WWTP
(Station 002)**

16. The muffin monster was broken. This needs to be repaired immediately.
17. The blowers were running and the plant was receiving good aeration.
18. The contents of the aeration tank were medium brown in color and no foam was present.
19. Both the sludge return line and skimmer return line were functioning properly. A new skimmer was installed in 2008.
20. The weirs in the settling tank were free of scum build-up.
21. A significant amount of pin floc was present in the settling tank.
22. Both surface sand filter beds were free of vegetation and solids build-up. New filter media was recently installed in the beds.
23. No sludge has been removed from the plant in the past three years. Mr. Shiner indicated he was going to waste sludge and re-seed the plant with sludge from the Campground Area WWTP.
24. Chlorination and dechlorination tablets were present in the disinfection vault. However, the dechlorination dispensing unit was broken and the dechlorination tablets were lying in the bottom of the tank. Mr. Shiner indicated this has been broken all season. This needs to be repaired for next season.
25. Effluent in the bottom of the vault was clear.
26. Two new lift station pumps and four new float switches were installed recently along with an alarm system for the lift station.
27. Mr. Shiner indicated that a bubbler was going to be installed in the disinfection vault.

This office has recently reviewed your self-monitoring reports covering the period March 1, 2007 through September 30, 2009 for the referenced facility. Our review indicates violations of the terms and conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Limit Violations

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residue	1D Conc	0.019	.08	6/10/2007
001	00610	Nitrogen, Ammonia (NH3	30D Conc	2.0	25.2	7/1/2007
001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.61	1.33535	7/1/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.11	7/6/2007
001	00610	Nitrogen, Ammonia (NH3	1D Conc	3.0	25.2	7/10/2007
001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.91	1.33535	7/10/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.11	7/10/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	7/11/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.21	7/12/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	7/13/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.07	7/16/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	7/17/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.08	7/19/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	7/20/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	7/28/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	7/30/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.16	7/31/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.22	8/1/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.14	8/2/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.1	8/4/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	8/6/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.13	8/7/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	8/10/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	8/12/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.13	8/14/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	8/17/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.09	8/18/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.15	8/19/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.07	8/27/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	8/28/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	8/29/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.08	8/30/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.08	8/31/2007
001	00610	Nitrogen, Ammonia (NH3	30D Conc	2.0	3.725	9/1/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	9/1/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.08	9/2/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.13	9/3/2007
001	00610	Nitrogen, Ammonia (NH3	1D Conc	3.0	7.14	9/4/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.08	9/4/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.07	9/5/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.11	9/6/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.22	9/7/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	9/8/2007

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	9/9/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.17	9/14/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.17	9/15/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	9/16/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	9/17/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.12	9/21/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.15	9/22/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	9/25/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	5/6/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	5/7/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	5/31/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	6/29/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	7/2/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	7/10/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	7/11/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	7/13/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.11	7/14/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	7/15/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.11	7/16/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	7/20/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	7/25/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	2.415	8/1/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	8/4/2008
001	00400	pH	1D Conc	6.5	6.44	8/5/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	8/6/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.08	8/7/2008
001	00400	pH	1D Conc	6.5	6.47	8/8/2008
001	00400	pH	1D Conc	6.5	6.28	8/10/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	8/10/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.08	8/16/2008
001	00400	pH	1D Conc	6.5	6.46	8/17/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.11	8/17/2008
001	00400	pH	1D Conc	6.5	6.45	8/19/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.08	8/19/2008
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3.0	4.73	8/20/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	8/20/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	8/21/2008
001	00400	pH	1D Conc	6.5	6.2	8/22/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	8/22/2008
001	00400	pH	1D Conc	6.5	6.44	8/24/2008
001	00400	pH	1D Conc	6.5	6.26	8/26/2008
001	00530	Total Suspended Solids	30D Conc	12	14.5	9/1/2008
001	80082	CBOD 5 day	30D Conc	10	14	9/1/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	9/3/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	9/4/2008

Mr. Phil Vichosky
Pymatuning WWTP
October 23, 2009
Page 5

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	9/5/2008
001	00400	pH	1D Conc	6.5	6.49	9/7/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	9/14/2008
001	00530	Total Suspended Solids	1D Conc	18	19.	9/17/2008
001	00400	pH	1D Conc	9.0	9.35	9/18/2008
001	00400	pH	1D Conc	9.0	9.13	9/24/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.07	9/24/2008
001	00400	pH	1D Conc	9.0	9.22	9/27/2008
001	80082	CBOD 5 day	30D Conc	10	18.5	10/1/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	10/2/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	10/8/2008
001	80082	CBOD 5 day	1D Conc	15	22.	10/8/2008
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	10/9/2008
001	00400	pH	1D Conc	6.5	6.19	10/26/2008
001	80082	CBOD 5 day	30D Conc	10	10.5	11/1/2008
001	80082	CBOD 5 day	30D Conc	10	22.	12/1/2008
001	80082	CBOD 5 day	1D Conc	15	22.	12/3/2008
001	00400	pH	1D Conc	6.5	6.17	1/1/2009
001	00400	pH	1D Conc	6.5	6.37	1/11/2009
001	00400	pH	1D Conc	6.5	6.48	1/14/2009
001	00400	pH	1D Conc	6.5	6.15	1/18/2009
001	00400	pH	1D Conc	6.5	6.41	1/19/2009
001	00400	pH	1D Conc	6.5	6.48	2/5/2009
001	00400	pH	1D Conc	6.5	6.35	2/8/2009
001	00400	pH	1D Conc	6.5	6.35	2/9/2009
001	00400	pH	1D Conc	6.5	6.29	2/10/2009
001	00400	pH	1D Conc	6.5	6.02	2/15/2009
001	00400	pH	1D Conc	6.5	6.21	2/16/2009
001	00400	pH	1D Conc	6.5	6.15	2/18/2009
001	00400	pH	1D Conc	6.5	6.31	4/28/2009
001	80082	CBOD 5 day	30D Conc	10	11.75	5/1/2009
001	00400	pH	1D Conc	6.5	6.03	5/3/2009
001	00400	pH	1D Conc	6.5	6.13	5/4/2009
001	00400	pH	1D Conc	6.5	6.35	5/9/2009
001	00400	pH	1D Conc	6.5	6.07	5/10/2009
001	00400	pH	1D Conc	6.5	6.02	5/11/2009
001	00400	pH	1D Conc	6.5	6.01	5/12/2009
001	00400	pH	1D Conc	6.5	6.09	5/17/2009
001	00400	pH	1D Conc	6.5	6.17	5/18/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	5/20/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	5/23/2009
001	00400	pH	1D Conc	6.5	6.13	5/24/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.12	5/24/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.07	5/27/2009
001	80082	CBOD 5 day	1D Conc	15	19.	5/27/2009

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	5/28/2009
001	00400	pH	1D Conc	6.5	6.28	5/31/2009
001	00400	pH	1D Conc	6.5	6.15	6/2/2009
001	00400	pH	1D Conc	6.5	6.2	6/3/2009
001	00400	pH	1D Conc	6.5	6.24	6/4/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	6/5/2009
001	00400	pH	1D Conc	6.5	6.43	6/6/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.12	6/6/2009
001	00400	pH	1D Conc	6.5	6.34	6/7/2009
001	00400	pH	1D Conc	6.5	6.32	6/8/2009
001	00400	pH	1D Conc	6.5	6.41	6/9/2009
001	00400	pH	1D Conc	6.5	6.44	6/11/2009
001	00400	pH	1D Conc	6.5	6.41	6/12/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.14	6/12/2009
001	00400	pH	1D Conc	6.5	6.27	6/13/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	6/13/2009
001	00400	pH	1D Conc	6.5	6.4	6/14/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.12	6/15/2009
001	00400	pH	1D Conc	6.5	6.43	6/16/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	6/17/2009
001	00400	pH	1D Conc	6.5	6.46	6/21/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.12	6/21/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	6/25/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.08	6/26/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.22	6/27/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	6/29/2009
001	00610	Nitrogen, Ammonia (NH3	1D Conc	3.0	10.5	7/1/2009
001	00610	Nitrogen, Ammonia (NH3	30D Conc	2.0	20.25	7/1/2009
001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.61	1.35976	7/1/2009
001	80082	CBOD 5 day	30D Conc	10	12.5	7/1/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	7/3/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.08	7/5/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	7/8/2009
001	80082	CBOD 5 day	1D Conc	15	19.	7/8/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.07	7/10/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	7/16/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.08	7/19/2009
001	00610	Nitrogen, Ammonia (NH3	1D Conc	3.0	30.	7/23/2009
001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.91	2.0439	7/23/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.11	7/24/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.06	7/25/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.09	7/26/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	8/5/2009
001	00400	pH	1D Conc	6.5	6.46	8/10/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.08	8/17/2009

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	8/18/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.08	8/19/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.09	8/24/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.25	8/25/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	9/6/2009
001	00400	pH	1D Conc	6.5	6.26	9/7/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.13	9/7/2009
001	50060	Chlorine, Total Residue	1D Conc	0.019	.05	9/13/2009
002	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	9.37	8/1/2007
002	00610	Nitrogen, Ammonia (NH3)	1D Conc	3.0	9.37	8/14/2007
002	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	8.725	9/1/2007
002	00610	Nitrogen, Ammonia (NH3)	1D Conc	3.0	17.4	9/4/2007
002	50060	Chlorine, Total Residue	1D Conc	0.019	.07	6/1/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.05	6/6/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.05	6/7/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.06	6/8/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.07	6/17/2008
002	31616	Fecal Coliform	30D Conc	1000	1300.	7/1/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.05	7/10/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.09	7/14/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.08	7/15/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.05	7/16/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.06	7/17/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.06	7/20/2008
002	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	18.5	8/1/2008
002	31616	Fecal Coliform	30D Conc	1000	1300.	8/1/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.05	8/4/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.05	8/5/2008
002	00610	Nitrogen, Ammonia (NH3)	1D Conc	3.0	18.5	8/6/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.06	8/6/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.06	8/7/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.05	8/17/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.06	8/25/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.05	8/26/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.06	8/29/2008
002	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	2.27	9/1/2008
002	50060	Chlorine, Total Residue	1D Conc	0.019	.05	9/9/2008
002	80082	CBOD 5 day	30D Conc	10	13.	5/1/2009
002	50060	Chlorine, Total Residue	1D Conc	0.019	.18	5/25/2009
002	50060	Chlorine, Total Residue	1D Conc	0.019	.13	5/26/2009
002	50060	Chlorine, Total Residue	1D Conc	0.019	.1	6/12/2009
002	50060	Chlorine, Total Residue	1D Conc	0.019	.07	6/21/2009
002	50060	Chlorine, Total Residue	1D Conc	0.019	.15	6/25/2009
002	50060	Chlorine, Total Residue	1D Conc	0.019	.06	6/26/2009
002	50060	Chlorine, Total Residue	1D Conc	0.019	.09	6/28/2009

Mr. Phil Vichosky
Pymatuning WWTP
October 23, 2009
Page 8

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
002	50060	Chlorine, Total Residue	1D Conc	0.019	.44	6/29/2009
002	50060	Chlorine, Total Residue	1D Conc	0.019	.08	7/5/2009
002	50060	Chlorine, Total Residue	1D Conc	0.019	1.03	7/15/2009
002	50060	Chlorine, Total Residue	1D Conc	0.019	2.06	7/16/2009
002	50060	Chlorine, Total Residue	1D Conc	0.019	3.67	7/17/2009
002	50060	Chlorine, Total Residue	1D Conc	0.019	.06	7/20/2009
002	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	3.	8/1/2009
002	00300	Dissolved Oxygen	1D Conc	6.0	5.9	8/4/2009
002	50060	Chlorine, Total Residue	1D Conc	0.019	.14	8/9/2009
002	00300	Dissolved Oxygen	1D Conc	6.0	5.9	8/12/2009
002	50060	Chlorine, Total Residue	1D Conc	0.019	.11	9/5/2009

This office has no record of the March 2007 through May 2007 discharge monitoring reports being submitted. Please submit this data immediately.

Please be advised that such instances of noncompliance may be cause for enforcement actions pursuant to the Ohio Revised Code, Chapter 6111.

Please inform this office in writing, within 21 days receipt of this letter your intentions to address items 1, 8, 13-16, and 24. The letter should include dates either actual or proposed for completion of the actions. A follow-up inspection will be conducted subsequent to the final completion date.

Should you have any comments or questions concerning this letter, please feel free to call me at (330) 963-1143.

Respectfully,



Michael W. Stevens
Environmental Engineer
Division of Surface Water

MWS/mt

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Phil Vichosky
 PO Box 1000
 Andover OH 44003

2. Article Number

(Transfer from service label) 7009 1680 0000 6381 1749 (Steven 10/23/09)

COMPLETE THIS SECTION ON DELIVERY

A. Signature

W. D. D. D.

- Agent
 Addressee

B. Received by (Printed Name)

WILLIAM D. D.

C. Date of Delivery

10/24/09

D. Is delivery address different from item 1? Yes
 If YES, enter delivery address below: No


3. Service Type

- Certified Mail Express Mail
 Registered Return Receipt for Merchandise
 Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee)

Yes

7009 1680 0000 6381 1749



Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$

Postmark Here

Sent To

Street, Apt. No.,
 or PO Box No.

City, State, ZIP+4