



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 31, 2008

RE: ASHTABULA COUNTY
HARPERSFIELD TOWNSHIP
KENISEE GRAND RIVER
CAMPGROUND
OHIO EPA PERMIT NO.
3PR00391

Mr. Curt Grey, Owner
Kenisee Grand River Campground
4680 State Route 307
Geneva, Ohio 44041

Dear Mr. Grey:

On July 8, 2008, an inspection was conducted at the above referenced facility by the undersigned. The purpose of the inspection was to evaluate the operation and maintenance of the plant for compliance with the above noted permit.

A review of the facility's compliance status during the period August 1, 2006 through July 1, 2008, indicates the following permit violations have occurred:

Limit Violations

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
August 2006	601	Fecal Coliform	1D Conc	23	610.	8/8/2006
June 2007	601	Total Suspended Solids	30D Conc	12	80.	6/1/2007
June 2007	601	Total Suspended Solids	30D Qty	0.23	1.514	6/1/2007
June 2007	601	Nitrogen, Ammonia (NH3)	30D Conc	1.0	43.4	6/1/2007
June 2007	601	Nitrogen, Ammonia (NH3)	30D Qty	0.019	.82135	6/1/2007
June 2007	601	Fecal Coliform	1D Conc	23	600.	6/5/2007
June 2007	601	Total Suspended Solids	7D Conc	18	80.	6/8/2007
June 2007	601	Total Suspended Solids	7D Qty	0.34	1.514	6/8/2007
June 2007	601	Nitrogen, Ammonia (NH3)	7D Conc	1.5	43.4	6/8/2007
June 2007	601	Nitrogen, Ammonia (NH3)	7D Qty	0.028	.82135	6/8/2007
June 2007	601	Dissolved Oxygen	1D Conc	6.0	5.4	6/14/2007
August 2007	601	Total Suspended Solids	30D Conc	12	15.	8/1/2007
August 2007	601	Total Suspended Solids	30D Qty	0.23	.28388	8/1/2007
August 2007	601	Fecal Coliform	1D Conc	23	50.	8/14/2007
June 2008	601	Fecal Coliform	1D Conc	23	900.	6/19/2008

Frequency Violations

MR. CURT GREY, OWNER
 KENISEE GRAND RIVER CAMPGROUND
 JULY 31, 2008
 PAGE 2

Reporting Period		Station	Parameter	Sample Frequency	Expected	Reported	Violation Date
August	2006	601	Fecal Coliform	1/Week	1	0	08/01/2006
August	2006	601	CBOD 5 day	1/Week	1	0	08/01/2006
August	2006	601	Chlorine, Total Residu	1/Week	1	0	08/01/2006
August	2006	601	Fecal Coliform	1/Week	1	0	08/15/2006
August	2006	601	CBOD 5 day	1/Week	1	0	08/15/2006
August	2006	601	Chlorine, Total Residu	1/Week	1	0	08/15/2006
August	2006	601	Fecal Coliform	1/Week	1	0	08/22/2006
August	2006	601	CBOD 5 day	1/Week	1	0	08/22/2006
August	2006	601	Chlorine, Total Residu	1/Week	1	0	08/22/2006
September	2006	601	Fecal Coliform	1/Week	1	0	09/01/2006
September	2006	601	CBOD 5 day	1/Week	1	0	09/01/2006
September	2006	601	Chlorine, Total Residu	1/Week	1	0	09/01/2006
September	2006	601	pH	1/Quarter	1	0	09/01/2006
September	2006	601	Fecal Coliform	1/Week	1	0	09/08/2006
September	2006	601	CBOD 5 day	1/Week	1	0	09/08/2006
September	2006	601	Chlorine, Total Residu	1/Week	1	0	09/08/2006
September	2006	601	Fecal Coliform	1/Week	1	0	09/15/2006
September	2006	601	CBOD 5 day	1/Week	1	0	09/15/2006
September	2006	601	Chlorine, Total Residu	1/Week	1	0	09/15/2006
September	2006	601	Fecal Coliform	1/Week	1	0	09/22/2006
September	2006	601	CBOD 5 day	1/Week	1	0	09/22/2006
September	2006	601	Chlorine, Total Residu	1/Week	1	0	09/22/2006
October	2006	601	Fecal Coliform	1/Week	1	0	10/01/2006
October	2006	601	CBOD 5 day	1/Week	1	0	10/01/2006
October	2006	601	Chlorine, Total Residu	1/Week	1	0	10/01/2006
October	2006	601	pH	1/Quarter	1	0	10/01/2006
October	2006	601	Fecal Coliform	1/Week	1	0	10/08/2006
October	2006	601	CBOD 5 day	1/Week	1	0	10/08/2006
October	2006	601	Chlorine, Total Residu	1/Week	1	0	10/08/2006
October	2006	601	Fecal Coliform	1/Week	1	0	10/15/2006
October	2006	601	CBOD 5 day	1/Week	1	0	10/15/2006
October	2006	601	Chlorine, Total Residu	1/Week	1	0	10/15/2006
October	2006	601	Fecal Coliform	1/Week	1	0	10/22/2006
October	2006	601	CBOD 5 day	1/Week	1	0	10/22/2006
October	2006	601	Chlorine, Total Residu	1/Week	1	0	10/22/2006
April	2007	601	CBOD 5 day	1/Week	1	0	04/01/2007
April	2007	601	Chlorine, Total Residu	1/Week	1	0	04/01/2007
April	2007	601	pH	1/Quarter	1	0	04/01/2007
April	2007	601	CBOD 5 day	1/Week	1	0	04/08/2007
April	2007	601	Chlorine, Total Residu	1/Week	1	0	04/08/2007
April	2007	601	CBOD 5 day	1/Week	1	0	04/15/2007
April	2007	601	Chlorine, Total Residu	1/Week	1	0	04/15/2007
April	2007	601	CBOD 5 day	1/Week	1	0	04/22/2007

MR. CURT GREY, OWNER
 KENISEE GRAND RIVER CAMPGROUND
 JULY 31, 2008
 PAGE 3

Reporting Period	Station	Parameter	Sample Frequency	Expected	Reported	Violation Date
April 2007	601	Chlorine, Total Residu	1/Week	1	0	04/22/2007
May 2007	601	Fecal Coliform	1/Week	1	0	05/01/2007
May 2007	601	CBOD 5 day	1/Week	1	0	05/01/2007
May 2007	601	Chlorine, Total Residu	1/Week	1	0	05/01/2007
May 2007	601	pH	1/Quarter	1	0	05/01/2007
May 2007	601	Fecal Coliform	1/Week	1	0	05/08/2007
May 2007	601	CBOD 5 day	1/Week	1	0	05/08/2007
May 2007	601	Chlorine, Total Residu	1/Week	1	0	05/08/2007
May 2007	601	Fecal Coliform	1/Week	1	0	05/15/2007
May 2007	601	CBOD 5 day	1/Week	1	0	05/15/2007
May 2007	601	Chlorine, Total Residu	1/Week	1	0	05/15/2007
May 2007	601	Fecal Coliform	1/Week	1	0	05/22/2007
May 2007	601	CBOD 5 day	1/Week	1	0	05/22/2007
May 2007	601	Chlorine, Total Residu	1/Week	1	0	05/22/2007
June 2007	601	CBOD 5 day	1/Week	1	0	06/01/2007
June 2007	601	Fecal Coliform	1/Week	1	0	06/08/2007
June 2007	601	Chlorine, Total Residu	1/Week	1	0	06/08/2007
June 2007	601	Fecal Coliform	1/Week	1	0	06/15/2007
June 2007	601	CBOD 5 day	1/Week	1	0	06/15/2007
June 2007	601	Chlorine, Total Residu	1/Week	1	0	06/15/2007
June 2007	601	Fecal Coliform	1/Week	1	0	06/22/2007
June 2007	601	CBOD 5 day	1/Week	1	0	06/22/2007
June 2007	601	Chlorine, Total Residu	1/Week	1	0	06/22/2007
July 2007	601	Fecal Coliform	1/Week	1	0	07/01/2007
July 2007	601	CBOD 5 day	1/Week	1	0	07/01/2007
July 2007	601	Chlorine, Total Residu	1/Week	1	0	07/01/2007
July 2007	601	pH	1/Quarter	1	0	07/01/2007
July 2007	601	Fecal Coliform	1/Week	1	0	07/08/2007
July 2007	601	CBOD 5 day	1/Week	1	0	07/08/2007
July 2007	601	Chlorine, Total Residu	1/Week	1	0	07/08/2007
July 2007	601	Fecal Coliform	1/Week	1	0	07/15/2007
July 2007	601	CBOD 5 day	1/Week	1	0	07/15/2007
July 2007	601	Chlorine, Total Residu	1/Week	1	0	07/15/2007
July 2007	601	Fecal Coliform	1/Week	1	0	07/22/2007
July 2007	601	CBOD 5 day	1/Week	1	0	07/22/2007
July 2007	601	Chlorine, Total Residu	1/Week	1	0	07/22/2007
August 2007	601	Fecal Coliform	1/Week	1	0	08/01/2007
August 2007	601	CBOD 5 day	1/Week	1	0	08/01/2007
August 2007	601	Chlorine, Total Residu	1/Week	1	0	08/01/2007
August 2007	601	Water Temperature	1/Week	1	0	08/15/2007
August 2007	601	Color, Severity	1/Week	1	0	08/15/2007
August 2007	601	Odor, Severity	1/Week	1	0	08/15/2007
August 2007	601	Turbidity, Severity	1/Week	1	0	08/15/2007

MR. CURT GREY, OWNER
 KENISEE GRAND RIVER CAMPGROUND
 JULY 31, 2008
 PAGE 4

Reporting Period	Station	Parameter	Sample Frequency	Expected	Reported	Violation Date
August 2007	601	Fecal Coliform	1/Week	1	0	08/15/2007
August 2007	601	CBOD 5 day	1/Week	1	0	08/15/2007
August 2007	601	Chlorine, Total Residu	1/Week	1	0	08/15/2007
August 2007	601	Fecal Coliform	1/Week	1	0	08/22/2007
August 2007	601	CBOD 5 day	1/Week	1	0	08/22/2007
August 2007	601	Chlorine, Total Residu	1/Week	1	0	08/22/2007
September 2007	601	Fecal Coliform	1/Week	1	0	09/01/2007
September 2007	601	CBOD 5 day	1/Week	1	0	09/01/2007
September 2007	601	Chlorine, Total Residu	1/Week	1	0	09/01/2007
September 2007	601	pH	1/Quarter	1	0	09/01/2007
September 2007	601	Fecal Coliform	1/Week	1	0	09/08/2007
September 2007	601	CBOD 5 day	1/Week	1	0	09/08/2007
September 2007	601	Chlorine, Total Residu	1/Week	1	0	09/08/2007
September 2007	601	Fecal Coliform	1/Week	1	0	09/15/2007
September 2007	601	CBOD 5 day	1/Week	1	0	09/15/2007
September 2007	601	Chlorine, Total Residu	1/Week	1	0	09/15/2007
September 2007	601	Fecal Coliform	1/Week	1	0	09/22/2007
September 2007	601	CBOD 5 day	1/Week	1	0	09/22/2007
September 2007	601	Chlorine, Total Residu	1/Week	1	0	09/22/2007
October 2007	601	Fecal Coliform	1/Week	1	0	10/01/2007
October 2007	601	CBOD 5 day	1/Week	1	0	10/01/2007
October 2007	601	Chlorine, Total Residu	1/Week	1	0	10/01/2007
October 2007	601	pH	1/Quarter	1	0	10/01/2007
October 2007	601	Fecal Coliform	1/Week	1	0	10/08/2007
October 2007	601	CBOD 5 day	1/Week	1	0	10/08/2007
October 2007	601	Chlorine, Total Residu	1/Week	1	0	10/08/2007
October 2007	601	Fecal Coliform	1/Week	1	0	10/15/2007
October 2007	601	CBOD 5 day	1/Week	1	0	10/15/2007
October 2007	601	Chlorine, Total Residu	1/Week	1	0	10/15/2007
October 2007	601	Fecal Coliform	1/Week	1	0	10/22/2007
October 2007	601	CBOD 5 day	1/Week	1	0	10/22/2007
October 2007	601	Chlorine, Total Residu	1/Week	1	0	10/22/2007


Based on the above, the facility is considered to be in violation of the NPDES permit. Numerous limit and frequency violations occurred in 2007; however, it appears the violations have been corrected with only one violation occurring in 2008.

During the inspection, you inquired about the expansion of the facility. To expand, Ohio EPA will need to know the current flow to the treatment system to determine if the system can support the proposed expansion. Daily system flow data needs to be obtained to determine the current flow of the system.

MR. CURT GREY, OWNER
KENISEE GRAND RIVER CAMPGROUND
JULY 31, 2008
PAGE 5

If there are any questions or comments regarding this notification, please contact me at
(330) 963-1180.

Respectfully,

A handwritten signature in cursive script, appearing to read "Virginia Wilson".

Virginia Wilson, P.E.
Geological Engineer
Division of Surface Water

VW/mh

cc: Mark Lewis, P.E.

File: Semi-Public/Ashtabula/Kenisee Grand River Campground