OhioEPA
State of Ohio Environmental Protection Agency
Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 12, 2009

RE: ECHO DELL MHP
12844 ECHO DELL ROAD
COLUMBIANA COUNTY

NOTICE OF VIOLATION

Mr. Alexander Waliga
202 East Summit Road
Kent, OH 44240

Dear Mr. Waliga:

On January 6, 2009, this writer conducted an inspection of the wastewater treatment plant for the Echo Dell mobile home park. Your park manager was present at the time of the inspection, and the facility was in operation and appeared to be producing a marginal effluent. The intent of the inspection was to evaluate the system's operation and maintenance. The past nine months of monthly operating report data was evaluated. Attached to this letter is a table outlining all the reported effluent violations. The following are findings from the inspection:

1. The aeration tank had a weak brown color and the settling tank was producing a cloudy effluent. The siphon appeared to be operating normally. Final effluent from the plant was cloudy and contained visible solids. The aerated sludge holding tank appeared not to be operating. Screenings from the plant's settling tank were lying on the ground next to an empty bucket. These must be containerized and disposed of in a solid waste dumpster.

2. One sand filter was plugged and the other partially plugged. The filter walls were leaking and allowing effluent to run across the ground in an unauthorized discharge to waters of the state. Sand that has been cleaned from the filters is lying across the ground and creating a nuisance and a health hazard. Material removed from the sand filters must be dry and disposed of in a solid waste dumpster.

3. A review of our records from September 2007 through November 2008 indicates this plant is in significant noncompliance with its National Pollutant Discharge Elimination System (NPDES) permit. Ohio EPA guidance for the operation of the treatment plant can be found at the Agency Web site at:

http://www.epa.state.oh.us/dsw/documents/PacPlant2000.pdf

Violations of permit effluent limits are considered a violation of Ohio Revised Code 6111.07 and are subject to enforcement action per Ohio Revised Code 6111.99. Echo Dell must immediately comply with all conditions of the NPDES Permit 3PV00024*BD. **This facility is currently in significant noncompliance.**

This office realizes that you have committed to connect to the county sewer system when it is available, however, the existing system must maintain compliance with its NPDES Permit in the interim. This facility has all the necessary equipment to comply with its NPDES permit. The county system will be available shortly and you have submitted detail plans for a pump station and force main to connect to the county treatment plant. Failure to maintain compliance with this current NPDES permit may result in escalated enforcement actions.

By February 12, 2009, please respond in writing what your proposed course of action will be to correct the above deficiencies. The letter needs to include a time frame to complete the following:

1) All operational changes necessary to bring the plant into compliance.

2) The date that the construction for a pump station and force main to eliminate the package plant will be completed.

You may contact this office at (330) 963-1193 to discuss any questions you may have.

Respectfully,

Joseph E. Trocchio

Joseph E. Trocchio, P.E.
Environmental Engineer
Division of Surface Water

JET/mt

enclosures

cc: Lori J. Barnes, R.S., Columbiana County Health Department

ec: Ronald A. Bell, Enforcement Coordinator, Ohio EPA, DSW, NEDO

File: Semipublic/Columbiana County/Saint Clair Township/Echo Dell

ECHO DELL MHP EFFLUENT VIOLATIONS: SEPT 07 - NOV 08

Permit No	Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PV00024*CD	January 2008	Total Suspended Solids	1D Conc	18	30.	1/3/2008
3PV00024*CD	January 2008	Total Suspended Solids	1D Conc	18	52.	1/9/2008
3PV00024*CD	January 2008	Total Suspended Solids	1D Conc	18	78.	1/17/2008
3PV00024*CD	January 2008	Total Suspended Solids	1D Conc	18	66.	1/24/2008
3PV00024*CD	January 2008	Total Suspended Solids	30D Conc	12	56.5	1/1/2008
3PV00024*CD	January 2008	Total Suspended Solids	1D Qty	1.7	1.8168	1/3/2008
3PV00024*CD	January 2008	Total Suspended Solids	1D Qty	1.7	3.9364	1/9/2008
3PV00024*CD	January 2008	Total Suspended Solids	1D Qty	1.7	8.56167	1/17/2008
3PV00024*CD	January 2008	Total Suspended Solids	1D Qty	1.7	5.74563	1/24/2008
3PV00024*CD	January 2008	Total Suspended Solids	30D Qty	1.1	5.01513	1/1/2008
3PV00024*CD	January 2008	Nitrogen, Ammonia (NH3)	1D Conc	4.5	25.6	1/3/2008
3PV00024*CD	January 2008	Nitrogen, Ammonia (NH3)	1D Conc	4.5	22.4	1/17/2008
3PV00024*CD	January 2008	Nitrogen, Ammonia (NH3)	30D Conc	3.0	24.	1/1/2008
3PV00024*CD	January 2008	Nitrogen, Ammonia (NH3)	1D Qty	0.42	1.55034	1/3/2008
3PV00024*CD	January 2008	Nitrogen, Ammonia (NH3)	1D Qty	0.42	2.45874	1/17/2008
3PV00024*CD	January 2008	Nitrogen, Ammonia (NH3)	30D Qty	0.28	2.00454	1/1/2008
3PV00024*CD	January 2008	CBOD 5 day	1D Conc	15	26.	1/3/2008
3PV00024*CD	January 2008	CBOD 5 day	1D Conc	15	21.	1/9/2008
3PV00024*CD	January 2008	CBOD 5 day	1D Conc	15	49.	1/17/2008
3PV00024*CD	January 2008	CBOD 5 day	1D Conc	15	42.	1/24/2008
3PV00024*CD	October 2008	Total Suspended Solids	1D Conc	18	24.	10/16/2008
3PV00024*CD	October 2008	Total Suspended Solids	1D Qty	1.7	2.54352	10/16/2008
3PV00024*CD	October 2008	Nitrogen, Ammonia (NH3)	1D Conc	1.5	2.71	10/16/2008
3PV00024*CD	October 2008	Nitrogen, Ammonia (NH3)	30D Conc	1.0	1.475	10/1/2008
3PV00024*CD	October 2008	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.28721	10/16/2008
3PV00024*CD	October 2008	Nitrogen, Ammonia (NH3)	30D Qty	0.09	.15314	10/1/2008
3PV00024*CD	October 2008	Dissolved Oxygen	1D Conc	5.0	4.9	10/2/2008
3PV00024*CD	January 2008	CBOD 5 day	30D Conc	10	34.5	1/1/2008
3PV00024*CD	January 2008	CBOD 5 day	1D Qty	1.42	1.57456	1/3/2008
3PV00024*CD	January 2008	CBOD 5 day	1D Qty	1.42	1.5897	1/9/2008
3PV00024*CD	January 2008	CBOD 5 day	1D Qty	1.42	5.37849	1/17/2008
3PV00024*CD	January 2008	CBOD 5 day	1D Qty	1.42	3.65631	1/24/2008
3PV00024*CD	January 2008	CBOD 5 day	30D Qty	0.95	3.04976	1/1/2008
3PV00024*CD	January 2008	Dissolved Oxygen	1D Conc	5.0	3.8	1/3/2008
3PV00024*CD	January 2008	Dissolved Oxygen	1D Conc	5.0	1.7	1/9/2008
3PV00024*CD	January 2008	Dissolved Oxygen	1D Conc	5.0	2.5	1/17/2008
3PV00024*CD	January 2008	Dissolved Oxygen	1D Conc	5.0	2.2	1/24/2008
3PV00024*CD	September 2007	Total Suspended Solids	1D Conc	18	19.	9/4/2007
3PV00024*CD	September 2007	Total Suspended Solids	1D Qty	1.7	2.08554	9/4/2007
3PV00024*CD	September 2007	Nitrogen, Ammonia (NH3)	1D Conc	1.5	5.96	9/4/2007
3PV00024*CD	September 2007	Nitrogen, Ammonia (NH3)	30D Conc	1.0	3.57	9/1/2007
3PV00024*CD	September 2007	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.6542	9/4/2007
3PV00024*CD	September 2007	Nitrogen, Ammonia (NH3)	30D Qty	0.09	.3673	9/1/2007

Permit No	Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PV00024*CD	September 2007	Dissolved Oxygen	1D Conc	5.0	3.6	9/4/2007
3PV00024*CD	September 2007	Dissolved Oxygen	1D Conc	5.0	4.5	9/13/2007
3PV00024*CD	September 2007	Dissolved Oxygen	1D Conc	5.0	3.5	9/20/2007
3PV00024*CD	August 2008	Nitrogen, Ammonia (NH3)	1D Conc	1.5	1.57	8/4/2008
3PV00024*CD	August 2008	Nitrogen, Ammonia (NH3)	30D Conc	1.0	1.255	8/1/2008
3PV00024*CD	August 2008	Dissolved Oxygen	1D Conc	5.0	3.3	8/12/2008
3PV00024*CD	February 2008	Total Suspended Solids	1D Conc	18	24.	2/14/2008
3PV00024*CD	February 2008	Total Suspended Solids	1D Conc	18	46.	2/19/2008
3PV00024*CD	February 2008	Total Suspended Solids	1D Conc	18	76.	2/26/2008
3PV00024*CD	February 2008	Total Suspended Solids	30D Conc	12	38.5	2/1/2008
3PV00024*CD	February 2008	Total Suspended Solids	1D Qty	1.7	2.45268	2/14/2008
3PV00024*CD	February 2008	Total Suspended Solids	1D Qty	1.7	4.00453	2/19/2008
3PV00024*CD	February 2008	Total Suspended Solids	1D Qty	1.7	7.76682	2/26/2008
3PV00024*CD	February 2008	Total Suspended Solids	30D Qty	1.1	3.76797	2/1/2008
3PV00024*CD	February 2008	Nitrogen, Ammonia (NH3)	30D Conc	3.0	4.29	2/1/2008
3PV00024*CD	February 2008	Nitrogen, Ammonia (NH3)	1D Qty	0.42	.45465	2/7/2008
3PV00024*CD	February 2008	Nitrogen, Ammonia (NH3)	30D Qty	0.28	.45465	2/1/2008
3PV00024*CD	February 2008	CBOD 5 day	1D Conc	15	19.	2/7/2008
3PV00024*CD	February 2008	CBOD 5 day	1D Conc	15	25.	2/14/2008
3PV00024*CD	February 2008	CBOD 5 day	1D Conc	15	25.	2/19/2008
3PV00024*CD	February 2008	CBOD 5 day	1D Conc	15	23.	2/26/2008
3PV00024*CD	February 2008	CBOD 5 day	30D Conc	10	23.	2/1/2008
3PV00024*CD	February 2008	CBOD 5 day	1D Qty	1.42	2.01362	2/7/2008
3PV00024*CD	February 2008	CBOD 5 day	1D Qty	1.42	2.55488	2/14/2008
3PV00024*CD	February 2008	CBOD 5 day	1D Qty	1.42	2.17638	2/19/2008
3PV00024*CD	February 2008	CBOD 5 day	1D Qty	1.42	2.35049	2/26/2008
3PV00024*CD	February 2008	CBOD 5 day	30D Qty	0.95	2.27384	2/1/2008
3PV00024*CD	February 2008	Dissolved Oxygen	1D Conc	5.0	2.5	2/14/2008
3PV00024*CD	February 2008	Dissolved Oxygen	1D Conc	5.0	1.6	2/19/2008
3PV00024*CD	December 2007	Total Suspended Solids	1D Qty	1.7	1.82059	12/6/2007
3PV00024*CD	December 2007	Total Suspended Solids	1D Qty	1.7	2.4981	12/23/2007
3PV00024*CD	December 2007	Total Suspended Solids	30D Qty	1.1	1.43735	12/1/2007
3PV00024*CD	December 2007	Nitrogen, Ammonia (NH3)	1D Qty	0.42	.57789	12/23/2007
3PV00024*CD	December 2007	Nitrogen, Ammonia (NH3)	30D Qty	0.28	.41385	12/1/2007
3PV00024*CD	December 2007	CBOD 5 day	1D Conc	15	24.	12/18/2007
3PV00024*CD	December 2007	CBOD 5 day	1D Conc	15	20.	12/23/2007
3PV00024*CD	December 2007	CBOD 5 day	30D Conc	10	15.025	12/1/2007
3PV00024*CD	December 2007	CBOD 5 day	1D Qty	1.42	1.47615	12/11/2007
3PV00024*CD	December 2007	CBOD 5 day	1D Qty	1.42	2.18016	12/18/2007
3PV00024*CD	December 2007	CBOD 5 day	1D Qty	1.42	3.3308	12/23/2007
3PV00024*CD	December 2007	CBOD 5 day	30D Qty	0.95	1.85531	12/1/2007
3PV00024*CD	December 2007	Dissolved Oxygen	1D Conc	5.0	2.5	12/23/2007
3PV00024*CD	April 2008	Total Suspended Solids	1D Conc	18	78.	4/3/2008
3PV00024*CD	April 2008	Total Suspended Solids	1D Conc	18	68.	4/10/2008
3PV00024*CD	April 2008	Total Suspended Solids	1D Conc	18	37.	4/17/2008

Permit No	Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PV00024*CD	April 2008	Total Suspended Solids	1D Conc	18	31.	4/24/2008
3PV00024*CD	April 2008	Total Suspended Solids	30D Conc	12	53.5	4/1/2008
3PV00024*CD	April 2008	Total Suspended Solids	1D Qty	1.7	6.79029	4/3/2008
3PV00024*CD	April 2008	Total Suspended Solids	1D Qty	1.7	9.26568	4/10/2008
3PV00024*CD	April 2008	Total Suspended Solids	1D Qty	1.7	4.62149	4/17/2008
3PV00024*CD	April 2008	Total Suspended Solids	1D Qty	1.7	4.3414	4/24/2008
3PV00024*CD	April 2008	Total Suspended Solids	30D Qty	1.1	6.25471	4/1/2008
3PV00024*CD	April 2008	Nitrogen, Ammonia (NH3)	1D Conc	4.5	24.2	4/17/2008
3PV00024*CD	April 2008	Nitrogen, Ammonia (NH3)	30D Conc	3.0	13.45	4/1/2008
3PV00024*CD	April 2008	Nitrogen, Ammonia (NH3)	1D Qty	0.42	3.0227	4/17/2008
3PV00024*CD	April 2008	Nitrogen, Ammonia (NH3)	30D Qty	0.28	1.62887	4/1/2008
3PV00024*CD	April 2008	CBOD 5 day	1D Conc	15	23.	4/3/2008
3PV00024*CD	April 2008	CBOD 5 day	1D Conc	15	23.	4/10/2008
3PV00024*CD	April 2008	CBOD 5 day	1D Conc	15	21.	4/17/2008
3PV00024*CD	April 2008	CBOD 5 day	30D Conc	10	20.25	4/1/2008
3PV00024*CD	April 2008	CBOD 5 day	1D Qty	1.42	2.00227	4/3/2008
3PV00024*CD	April 2008	CBOD 5 day	1D Qty	1.42	3.13398	4/10/2008
3PV00024*CD	April 2008	CBOD 5 day	1D Qty	1.42	2.62301	4/17/2008
3PV00024*CD	April 2008	CBOD 5 day	1D Qty	1.42	1.96063	4/24/2008
3PV00024*CD	April 2008	CBOD 5 day	30D Qty	0.95	2.42997	4/1/2008
3PV00024*CD	April 2008	pH	1D Conc	6.5	6.	4/3/2008
3PV00024*CD	April 2008	pH	1D Conc	6.5	6.2	4/10/2008
3PV00024*CD	April 2008	pH	1D Conc	6.5	6.4	4/17/2008
3PV00024*CD	April 2008	Dissolved Oxygen	1D Conc	5.0	1.4	4/3/2008
3PV00024*CD	April 2008	Dissolved Oxygen	1D Conc	5.0	1.9	4/17/2008
3PV00024*CD	July 2008	Nitrogen, Ammonia (NH3)	30D Conc	1.0	1.28	7/1/2008
3PV00024*CD	July 2008	Nitrogen, Ammonia (NH3)	30D Qty	0.09	.11143	7/1/2008
3PV00024*CD	July 2008	Fecal Coliform	1D Conc	2000	2400.	7/1/2008
3PV00024*CD	July 2008	Fecal Coliform	30D Conc	1000	1219.83	7/1/2008
3PV00024*CD	July 2008	Dissolved Oxygen	1D Conc	5.0	2.1	7/3/2008
3PV00024*CD	July 2008	Dissolved Oxygen	1D Conc	5.0	2.4	7/10/2008
3PV00024*CD	July 2008	Dissolved Oxygen	1D Conc	5.0	2.9	7/17/2008
3PV00024*CD	July 2008	Dissolved Oxygen	1D Conc	5.0	2.9	7/24/2008
3PV00024*CD	May 2008	Total Suspended Solids	1D Conc	18	46.	5/20/2008
3PV00024*CD	May 2008	Total Suspended Solids	1D Conc	18	73.	5/27/2008
3PV00024*CD	May 2008	Total Suspended Solids	30D Conc	12	32.25	5/1/2008
3PV00024*CD	May 2008	Total Suspended Solids	1D Qty	1.7	3.30809	5/20/2008
3PV00024*CD	May 2008	Total Suspended Solids	1D Qty	1.7	4.14458	5/27/2008
3PV00024*CD	May 2008	Total Suspended Solids	30D Qty	1.1	2.13758	5/1/2008
3PV00024*CD	May 2008	Nitrogen, Ammonia (NH3)	1D Conc	1.5	14.3	5/7/2008
3PV00024*CD	May 2008	Nitrogen, Ammonia (NH3)	1D Conc	1.5	1.74	5/20/2008
3PV00024*CD	May 2008	Nitrogen, Ammonia (NH3)	30D Conc	1.0	8.02	5/1/2008
3PV00024*CD	May 2008	Nitrogen, Ammonia (NH3)	1D Qty	0.14	1.78614	5/7/2008
3PV00024*CD	May 2008	Nitrogen, Ammonia (NH3)	30D Qty	0.09	.95564	5/1/2008
3PV00024*CD	May 2008	CBOD 5 day	1D Conc	15	23.	5/20/2008

Permit No	Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PV00024*CD	May 2008	CBOD 5 day	1D Conc	15	48.	5/27/2008
3PV00024*CD	May 2008	CBOD 5 day	30D Conc	10	22.15	5/1/2008
3PV00024*CD	May 2008	CBOD 5 day	1D Qty	1.42	1.62377	5/7/2008
3PV00024*CD	May 2008	CBOD 5 day	1D Qty	1.42	1.65405	5/20/2008
3PV00024*CD	May 2008	CBOD 5 day	1D Qty	1.42	2.7252	5/27/2008
3PV00024*CD	May 2008	CBOD 5 day	30D Qty	0.95	1.60087	5/1/2008
3PV00024*CD	May 2008	pH	1D Conc	6.5	6.4	5/27/2008
3PV00024*CD	May 2008	Dissolved Oxygen	1D Conc	5.0	4.5	5/13/2008
3PV00024*CD	March 2008	Total Suspended Solids	1D Conc	18	22.	3/4/2008
3PV00024*CD	March 2008	Total Suspended Solids	1D Conc	18	39.	3/13/2008
3PV00024*CD	March 2008	Total Suspended Solids	1D Conc	18	107.	3/20/2008
3PV00024*CD	March 2008	Total Suspended Solids	1D Conc	18	29.	3/27/2008
3PV00024*CD	March 2008	Total Suspended Solids	30D Conc	12	49.25	3/1/2008
3PV00024*CD	March 2008	Total Suspended Solids	1D Qty	1.7	2.08175	3/4/2008
3PV00024*CD	March 2008	Total Suspended Solids	1D Qty	1.7	3.39515	3/13/2008
3PV00024*CD	March 2008	Total Suspended Solids	1D Qty	1.7	10.5298	3/20/2008
3PV00024*CD	March 2008	Total Suspended Solids	1D Qty	1.7	2.85389	3/27/2008
3PV00024*CD	March 2008	Total Suspended Solids	30D Qty	1.1	4.71516	3/1/2008
3PV00024*CD	March 2008	Nitrogen, Ammonia (NH3)	1D Conc	4.5	7.42	3/20/2008
3PV00024*CD	March 2008	Nitrogen, Ammonia (NH3)	30D Conc	3.0	5.445	3/1/2008
3PV00024*CD	March 2008	Nitrogen, Ammonia (NH3)	1D Qty	0.42	.7302	3/20/2008
3PV00024*CD	March 2008	Nitrogen, Ammonia (NH3)	30D Qty	0.28	.52928	3/1/2008
3PV00024*CD	March 2008	CBOD 5 day	1D Conc	15	30.	3/13/2008
3PV00024*CD	March 2008	CBOD 5 day	1D Conc	15	26.	3/20/2008
3PV00024*CD	March 2008	CBOD 5 day	1D Conc	15	59.	3/27/2008
3PV00024*CD	March 2008	CBOD 5 day	30D Conc	10	31.25	3/1/2008
3PV00024*CD	March 2008	CBOD 5 day	1D Qty	1.42	2.61165	3/13/2008
3PV00024*CD	March 2008	CBOD 5 day	1D Qty	1.42	2.55866	3/20/2008
3PV00024*CD	March 2008	CBOD 5 day	1D Qty	1.42	5.80619	3/27/2008
3PV00024*CD	March 2008	CBOD 5 day	30D Qty	0.95	2.98069	3/1/2008
3PV00024*CD	March 2008	pH	1D Conc	9.0	9.1	3/4/2008
3PV00024*CD	March 2008	Dissolved Oxygen	1D Conc	5.0	2.5	3/13/2008
3PV00024*CD	March 2008	Dissolved Oxygen	1D Conc	5.0	3.5	3/20/2008
3PV00024*CD	March 2008	Dissolved Oxygen	1D Conc	5.0	4.1	3/27/2008
3PV00024*CD	October 2007	Nitrogen, Ammonia (NH3)	1D Conc	1.5	2.68	10/4/2007
3PV00024*CD	October 2007	Nitrogen, Ammonia (NH3)	30D Conc	1.0	2.085	10/1/2007
3PV00024*CD	October 2007	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.18259	10/4/2007
3PV00024*CD	October 2007	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.16355	10/18/2007
3PV00024*CD	October 2007	Nitrogen, Ammonia (NH3)	30D Qty	0.09	.17307	10/1/2007
3PV00024*CD	October 2007	Dissolved Oxygen	1D Conc	5.0	4.6	10/11/2007
3PV00024*CD	September 2008	Total Suspended Solids	1D Conc	18	28.	9/18/2008
3PV00024*CD	September 2008	Total Suspended Solids	30D Conc	12	14.	9/1/2008
3PV00024*CD	September 2008	Total Suspended Solids	1D Qty	1.7	2.96744	9/18/2008
3PV00024*CD	September 2008	Total Suspended Solids	30D Qty	1.1	1.40802	9/1/2008
3PV00024*CD	September 2008	Nitrogen, Ammonia (NH3)	1D Conc	1.5	20.1	9/18/2008

Permit No	Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PV00024*CD	September 2008	Nitrogen, Ammonia (NH3)	30D Conc	1.0	10.49	9/1/2008
3PV00024*CD	September 2008	Nitrogen, Ammonia (NH3)	1D Qty	0.14	2.1302	9/18/2008
3PV00024*CD	September 2008	Nitrogen, Ammonia (NH3)	30D Qty	0.09	1.09674	9/1/2008
3PV00024*CD	September 2008	Fecal Coliform	1D Conc	2000	6300.	9/4/2008
3PV00024*CD	September 2008	Fecal Coliform	1D Conc	2000	7100.	9/18/2008
3PV00024*CD	September 2008	Fecal Coliform	30D Conc	1000	6688.04	9/1/2008
3PV00024*CD	September 2008	CBOD 5 day	1D Conc	15	22.	9/18/2008
3PV00024*CD	September 2008	CBOD 5 day	1D Qty	1.42	2.33156	9/18/2008
3PV00024*CD	June 2008	Nitrogen, Ammonia (NH3)	1D Conc	1.5	2.3	6/5/2008
3PV00024*CD	June 2008	Nitrogen, Ammonia (NH3)	1D Conc	1.5	4.25	6/19/2008
3PV00024*CD	June 2008	Nitrogen, Ammonia (NH3)	30D Conc	1.0	3.275	6/1/2008
3PV00024*CD	June 2008	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.19152	6/5/2008
3PV00024*CD	June 2008	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.32173	6/19/2008
3PV00024*CD	June 2008	Nitrogen, Ammonia (NH3)	30D Qty	0.09	.25662	6/1/2008
3PV00024*CD	June 2008	Fecal Coliform	1D Conc	2000	4300.	6/5/2008
3PV00024*CD	June 2008	Fecal Coliform	30D Conc	1000	4300.	6/1/2008
3PV00024*CD	June 2008	CBOD 5 day	1D Conc	15	29.	6/5/2008
3PV00024*CD	June 2008	CBOD 5 day	30D Conc	10	10.425	6/1/2008
3PV00024*CD	June 2008	CBOD 5 day	1D Qty	1.42	2.41483	6/5/2008
3PV00024*CD	June 2008	pH	1D Conc	6.5	6.2	6/10/2008
3PV00024*CD	June 2008	Dissolved Oxygen	1D Conc	5.0	2.2	6/10/2008
3PV00024*CD	June 2008	Dissolved Oxygen	1D Conc	5.0	3.	6/26/2008