



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

July 31, 2007

RE: NEOSA SALVATION ARMY CAMP  
5037 EDGEWOOD RD. SW  
MONROE TWP.  
CARROLL COUNTY

Captain Jim Betts  
NEO Salvation Army Camp  
5037 Edgewood Rd. SW  
Carrollton, OH 44615

Dear Mr. Betts:

On June 12, 2007, this writer conducted an inspection of the wastewater treatment plant for the NEO Salvation Army Camp. Mr. Bob Bird, camp care taker, was there on behalf of the camp. The intent of the inspection was to conduct a compliance evaluation inspection and evaluate operations and maintenance of the system. The following are findings from the inspection.

1. A summary of the wastewater treatment plant discharge violations for the last two years and three months has been attached to this letter. There have only been a few violations and none since February 2007.
2. The aeration tanks had a weak color and a low biological solids level.
3. The effluent of the clarifiers was relatively free of solids and appeared to be producing a satisfactory effluent.
4. The surface sand filters were in satisfactory condition.
5. The phosphorus removal equipment was not in service. There were three phosphorus violations in 2006. If the treatment plant cannot maintain its permit requirements without chemical addition, then this equipment must be returned to good working order. Failure to keep equipment operational is a violation of your NPDES permit.

Please respond in writing by August 15, 2007, what your proposed course of action will be to correct the attached violations. The letter needs to include a time frame to complete any operational or equipment changes to prevent any future violations.

You may contact this office at (330) 963-1193 to discuss any questions you may have.

Respectfully,

Joseph E. Trocchio  
Environmental Engineer  
Division of Surface Water

JET/mt

enclosures (1)

cc: Carroll County Health Dept.

File: Semipublic/Carroll County/Monroe Township/NEOSA SALVATION ARMY CAMP

### NEOSA SALVATION ARM CAMP VIOLATIONS: MARCH 2005 - JUNE 2007

Permit No	Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PR00223*BD	February 2007	Dissolved Oxygen	1D Conc	6.0	4.8	2/15/2007
3PR00223*BD	April 2005	Total Suspended Solids	30D Conc	10	12.	4/1/2005
3PR00223*BD	August 2005	Dissolved Oxygen	1D Conc	6.0	5.8	8/17/2005
3PR00223*BD	May 2006	Dissolved Oxygen	1D Conc	6.0	5.4	5/4/2006
3PR00223*BD	September 2006	Phosphorus, Total (P)	30D Conc	4	5.51	9/1/2006
3PR00223*BD	August 2006	Phosphorus, Total (P)	30D Conc	4	7.86	8/1/2006
3PR00223*BD	August 2006	Phosphorus, Total (P)	7D Conc	6	7.86	8/1/2006
3PR00223*BD	April 2006	Dissolved Oxygen	1D Conc	6.0	5.6	4/13/2006
3PR00223*BD	April 2006	Dissolved Oxygen	1D Conc	6.0	5.9	4/27/2006
3PR00223*BD	July 2006	Dissolved Oxygen	1D Conc	6.0	2.5	7/20/2006
3PR00223*BD	October 2006	Dissolved Oxygen	1D Conc	6.0	5.3	10/5/2006
3PR00223*BD	December 2006	Dissolved Oxygen	1D Conc	6.0	5.1	12/7/2006