

**Environmental  
Protection Agency**

Timothy J. White, Governor  
Lee P. Fisher, Lt. Governor  
Chris M. Weisberg, Director

July 23, 2010

RE: CAMP ROOSEVELT/FIREBIRD  
4141 DUBLIN ROAD  
ORANGE TWP.  
CARROLL COUNTY

Mr. Andrew Schwartz, Managing Member  
Camp Firebird LLC  
4141 Dublin Road, S.W.  
Bowerston, OH 44695

Dear Mr. Schwartz:

On July 8, 2010, this writer conducted an inspection of the wastewater treatment plant for the Camp Roosevelt/Firebird. The facility was represented by Debbie Collins. The intent of the inspection was to evaluate operations and maintenance of the system. The following are findings from the inspection.

1. The facilities consist of a trash trap, followed by a 6,000-gpd extended aeration treatment plant, dosing chamber, surface sand filter, and chlorination facilities. Final effluent is discharged through a pump station to an Evapo-transpiration Lagoon at the top of the hill. At the time of the inspection, the treatment plant appeared to be operating satisfactorily.
2. The aeration tank had a good brown color. The air diffuser in the north tank needed replaced. The sludge return on the east side of the tank was not operating and needed repaired. The surface sand filters had some weeds that need to be killed off but appeared to be operating. The trash trap appeared satisfactory. The tablet chlorinator had the appropriate chlorine tablets.
3. The monthly operating report data was reviewed for the period of January 2009 through June 2010. The data revealed a few dissolved oxygen violations and one suspended solids violation. There have been no violations since January 2010. A list of the violations has been included below.

CAMP ROOSEVELT/FIREBIRD LLC EFFLUENT VIOLATIONS: JAN. 2009 - JUNE 2010						
Permit No	Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PR00461*AD	June 2009	Dissolved Oxygen	1D Conc	6.0	4.	6/16/2009
3PR00461*BD	September 2009	Dissolved Oxygen	1D Conc	6.0	2.58	9/7/2009
3PR00461*BD	September 2009	Dissolved Oxygen	1D Conc	6.0	3.26	9/12/2009
3PR00461*BD	October 2009	Dissolved Oxygen	1D Conc	6.0	1.64	10/1/2009
3PR00461*BD	October 2009	Dissolved Oxygen	1D Conc	6.0	5.88	10/10/2009
3PR00461*BD	October 2009	Dissolved Oxygen	1D Conc	6.0	5.4	10/21/2009
3PR00461*BD	October 2009	Dissolved Oxygen	1D Conc	6.0	4.7	10/26/2009
3PR00461*BD	January 2010	Dissolved Oxygen	1D Conc	6.0	.24	1/13/2010
3PR00461*BD	January 2010	Dissolved Oxygen	1D Conc	6.0	.5	1/25/2010
3PR00461*BD	November 2009	Dissolved Oxygen	1D Conc	6.0	5.82	11/14/2009
3PR00461*AD	January 2009	Total Suspended Solids	30D Conc	12	12.27	1/1/2009
3PR00461*BD	December 2009	Dissolved Oxygen	1D Conc	6.0	.63	12/6/2009

Mr. Andrew Schwartz  
Camp Roosevelt/Firebird  
July 23, 2010  
Page 2

By August 20, 2010, please respond in writing when the wastewater treatment plant has had the above mentioned items repaired

You may contact this office at (330) 963-1193 to discuss any questions you may have.

Respectfully,

A handwritten signature in black ink that reads "Joseph E. Trocchio". The signature is written in a cursive style with a large initial "J" and "T".

Joseph E. Trocchio, P.E.  
Environmental Engineer  
Division of Surface Water

JET/mt

cc: Carroll County Health Dept.  
Debbie Collins, Plant Operator

File: Semipublic/Carroll County/Orange Township/Camp Roosevelt/Firebird