



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 10, 2008

RE: HOLMES COUNTY
WALNUT CREEK TOWNSHIP
CHESTNUT RIDGE ELEMENTARY
3629 SR 39
NPDES 3PT00118

Mr. Junior Troyer
East Holmes Schools
P.O. Box 182
Berlin, OH 44610

Dear Mr. Troyer:

On September 9, 2008, this office conducted an inspection of the wastewater treatment plant serving the above referenced facility. Present during the inspection were this writer and Kraig Bucklew of the Holmes County Health Department.

At the time of the inspection, the system was producing what appeared to be a satisfactory quality effluent. The mixed liquor in the aeration tank had a light brown color and the clarifier effluent was clear. The surface sand filter beds were in very good condition and the contents of the chlorine contact tank were clear.

The chlorine contact tank still leaks and must be repaired. This was noted in my inspection letters from 2005, 2006, and 2007.

A review of your monthly operating reports covering the period September 2007 through August 2008 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
September 2007	001	Dissolved Oxygen	1D Conc	6.0	5.87	9/4/2007
March 2008	001	Total Suspended Solids	30D Conc	12	17	3/1/2008
March 2008	001	CBOD 5 day	30D Conc	10	14	3/1/2008
June 2008	001	Dissolved Oxygen	1D Conc	6.0	3	6/9/2008
June 2008	001	Dissolved Oxygen	1D Conc	6.0	2.21	6/16/2008
June 2008	001	Dissolved Oxygen	1D Conc	6.0	3.31	6/23/2008
July 2008	001	Dissolved Oxygen	1D Conc	6.0	5.29	7/2/2008
July 2008	001	Dissolved Oxygen	1D Conc	6.0	5.09	7/9/2008
July 2008	001	Dissolved Oxygen	1D Conc	6.0	3.18	7/15/2008
July 2008	001	Dissolved Oxygen	1D Conc	6.0	3.56	7/23/2008
August 2008	001	Dissolved Oxygen	1D Conc	6.0	5.07	8/8/2008

MR. JUNIOR TROYER
CHESTNUT RIDGE ELEMENTARY
SEPTEMBER 10, 2008
PAGE 2

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,

A handwritten signature in cursive script that reads "Dean Stoll".

Dean W. Stoll, P.E.
Environmental Engineer
Division of Surface Water

DWS/mlh

cc: Holmes County Health Department, Attn: Kraig Bucklew
Kevin Dean

File: Semi-Public/Chestnut Ridge Elementary