

SENDER: COMPLETE THIS SECTION	COMPLETE THIS SECTION ON DELIVERY	
<ul style="list-style-type: none"> ■ Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired. ■ Print your name and address on the reverse so that we can return the card to you. ■ Attach this card to the back of the mailpiece, or on the front if space permits. 	A. Signature  <input checked="" type="checkbox"/> Agent <input type="checkbox"/> Addressee	
1. Article Addressed to: MR. LEON TROYER 2972 TR 190 BALTIM, OH 43804	B. Received by (Printed Name) <i>LEON TROYER</i>	C. Date of Delivery <i>10/6/08</i>
2. Article Number <i>7008 0150 0001 7110 9538</i> <small>(Transfer from service label)</small>	D. Is delivery address different from item 1? <input checked="" type="checkbox"/> Yes If YES, enter delivery address below: <input type="checkbox"/> No	
	3. Service Type <input checked="" type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.	
	4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes	
	D. STOLL 11-4-08	



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 4, 2008

RE: HOLMES COUNTY
CLARK TOWNSHIP
MEL & MARY'S COTTAGES
2972 TR 190
NPDES 3PR00311

Mr. Leon Troyer
2972 TR 190
Baltic, OH 43804

CERTIFIED MAIL

Dear Mr. Troyer:

On October 29, 2008, this office conducted an inspection of the wastewater treatment plant serving the above referenced facility. Present during the inspection were this writer and Kraig Bucklew of the Holmes County Health Department.

The treatment system consists of an Orenco recirculating textile filter. The system was installed during October 2007. At the time of the inspection, the system was producing a clear effluent.

A review of your Discharge Monitoring Reports (DMRs) covering the period February 2008 through October 2008 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2008	001	Total Suspended Solids	30D Conc	12	17.	6/1/2008
June 2008	001	Nitrogen, Ammonia (NH3)	30D Conc	1.0	6.39	6/1/2008
June 2008	001	Nitrogen, Ammonia (NH3)	30D Qty	0.0057	.01451	6/1/2008
June 2008	001	CBOD 5 day	30D Conc	10	15.	6/1/2008
June 2008	001	Dissolved Oxygen	1D Conc	6.0	5.38	6/2/2008
June 2008	001	Nitrogen, Ammonia (NH3)	7D Conc	1.5	6.39	6/8/2008
June 2008	001	Nitrogen, Ammonia (NH3)	7D Qty	0.0085	.01451	6/8/2008
August 2008	001	Nitrogen, Ammonia (NH3)	30D Conc	1.0	11.	8/1/2008
August 2008	001	Nitrogen, Ammonia (NH3)	30D Qty	0.0057	.02498	8/1/2008
August 2008	001	Dissolved Oxygen	1D Conc	6.0	.72	8/1/2008
August 2008	001	Nitrogen, Ammonia (NH3)	7D Conc	1.5	11.	8/8/2008
August 2008	001	Nitrogen, Ammonia (NH3)	7D Qty	0.0085	.02498	8/8/2008


This treatment system has been in consistent non-compliance since it was installed. Based upon our experience with these systems, and there inability to meet NPDES permit effluent limitations, you should plan for upgrades or a replacement treatment system at this

MR. LEON TROYER
MEL & MARY'S COTTAGES
NOVEMBER 4, 2008
PAGE 2

time. Continued non-compliance will result in this matter being referred to our legal section for an enforcement action.

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,



Dean W. Stoll, P.E.
Environmental Engineer
Division of Surface Water

DWS/mlh

pc: Holmes County Health Department, Attn: Kraig Bucklew
Kevin Dean, Dean's Backflow Services

File: Semi-Public/Mel & Mary's Cottages

7008 0150 0001 7110 9538

U.S. Postal Service™
CERTIFIED MAIL™ RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)
For delivery information visit our website at www.usps.com

Postage	\$	
Certified Fee		
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
Total Postage & Fees	\$	

Postmark Here
D. STOLL
11-04-08
mlh

Sent To MR. LEON TROYER
Street, Apt. No.; 2972 TR 190
or PO Box No. BALTIMORE, OH 43804
City, State, ZIP+4

PS Form 3800, August 2006