OhioEPA

State of Ohio Environmental Protection Agency

STREET ADDRESS: **Central District Office** MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

September 9, 2010

Denis Crews
City Of Lancaster
121 E Chestnut St
Lancaster, Oh 43130

Re: Construction Storm Water Inspection at Upper Hocking WPCF/Pump Station/Force Main/Outfall Sewer / Fairfield County
Permit Number: 4GC02932*AG

Dear Mr. Crews:

This letter is written regarding a storm water inspection conducted by Stephen Riley of the Ohio EPA at Upper Hocking WPCF/Pump Station/Force Main/Outfall Sewer located at 1442 Campground Road, 1155 N Pierce Street, Lancaster, Ohio on August 24, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Our staff observed dewatering activities which resulted in a discharge into the Hocking River originating from the groundwater discharge pipe. Please contact the Ohio Department of Natural Resources, Division of Water, for a withdraw certification.

- Please monitor daily the discharge to the Hocking River to ensure there are no turbid discharges.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. All actions I have listed above require correction within three days from receipt of this letter unless otherwise noted.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, CDO/DSW

HK/nsm Uper Hocking WPCF Pump Station Force Main Ourfall Sewer 8-24-2010