



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

May 12, 2010

James Sisto  
Central Ohio Community Improvement Corporation  
919 Old Henderson Road  
Columbus, OH 43220

**Re: Storm Water Inspection Bedford Landfill Permit Number 4GC02548\*AG**

Dear Mr. Sisto:

This letter is written in follow-up to a construction storm water inspection I conducted at Bedford Landfill located in Gahanna, Ohio on April 29, 2010. The purpose of the inspection was to evaluate your compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

**Sediment and Erosion Controls:**

- The site was subject to stabilization efforts prior to the winter months. Approximately 50 to 60 percent of the site has been stabilized.
- Efforts must continue to stabilize the remainder of the site to ensure compliance with the General Permit. All remaining barren areas which are idle in excess of 21 days must be protected from erosion. Based on my observations, this appears to be the remainder of the site. Corrective measures to stabilize the entire site are expected within seven days from receipt of this letter.
- The site must be inspected and every seven days and within 24 hours of a precipitation event equal to or greater than 0.5 inches. All deficiencies must be logged and repaired in accordance with General Permit conditions. Generally deficiencies must be corrected within three days of discovery. The inspection logs must be maintained onsite available for review.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

James Sisto  
Central Ohio Community Improvement Corporation  
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). Please provide a written response to this letter within seven days.

Sincerely,



Jeffrey P. Boh  
For H.K.

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Ted Hunker, Tartan Golf & Management

HK/nsm Bedford 04-29-2010