



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

February 25, 2010

Kobil and Associates
5900 Sharon Woods Boulevard
Columbus, OH 43229

**Re: Construction Storm Water Inspection at Holiday Inn Express
Permit Number 4GC02874*AG**

Dear Sir or Madame:

This letter is written in follow-up to a construction storm water inspection I conducted at Holiday Inn Express located on Orion Place in Columbus, Ohio on February 22, 2010. The purpose of the inspection was to evaluate your compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls:

- Perimeter silt fence has failed due to recent storm events. Maintenance is required. Straw bales should back the silt fence for additional support.
- The sediment basin must be completed within 10 of the recommencement of construction.
- All affected areas which remain barren and idle in excess of 21 days must be protected from erosion. Given the current season, a crimped mulch cover is expected for temporary cover.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at:
[Http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx](http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx). Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Kobil and Associates
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. Please provide a response to this letter within seven (7) days of receipt.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/ct Holiday In Express 02-03-10 4GC02874