



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

October 18, 2010

Duff Michowski
Henkel Corp
421 London Road
PO Box 3636
Delaware, OH 43015

**Re: Construction Storm Water Inspection at Henkel Corp Graphite Processing Facility
Delaware County
Permit Number: 4GCO00034*AG**

Dear Mr. Michowski:

This letter is written regarding a storm water inspection conducted by Stephen Riley of the Ohio EPA at Henkel Corp Graphite Processing Facility located at 421 London Road Delaware, Ohio on September 30, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Dewatering:

- During the site investigation, it was found there were dewatering activities that were directed into the local storm sewer. Please be mindful of these activities so that they do not lead to turbid discharges to waters of the state, resulting in violations of ORC 6111.04.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Henkel Corp Graphite Processing Facility 9-30-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

