



State of Ohio Environmental Protection Agency

REET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

September 9, 2010

Tony Furgiuele  
Republic Services of Ohio III, LLC  
5131 Drinkle Road  
Amanda, OH 43102

**Re: Construction Storm Water Inspection at Pine Grove Regional Facility  
Fairfield County  
Permit Number: 4GC03262\*AG**

Dear Mr. Furgiuele:

This letter is written in follow-up to a construction storm water inspection conducted by Stephen Riley of Ohio EPA at Pine Grove Regional Facility in Amanda, Ohio on August 24, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- During the inspection, our staff noted evidence of heavy sediment flows moving relatively uncontrolled in the drainage ditch on the west side of the existing road. Please be aware erosion protection must be provided for all areas of final grade.
- There was evidence of equipment crossing a stream without the use of a temporary stream crossing. Corrective measures must be taken to install a temporary stream crossing constructed of non-erodible fill. The temporary stream crossing must incorporate provisions to pass normal flows through the crossing.
- Our staff observed the retention pond around the inlet has become overburdened with sediment. Please be aware sediment traps must be utilized for areas of concentrated flow and must be sized with a required sediment storage volume per the General Permit. These sediment impoundments require cleaning once they have exceeded 50 percent of their capacity.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



Tony Furgiuele  
Republic Services of Ohio III, LLC  
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Pine Grove Regional Facility 8-24-2010